

PROBLEM SUMMARY

Sample Rating Trend




Machine Id KAESER BSD 50 5085453 (S/N 1212)

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

No corrective action is recommended at this time. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS									
Sample Status			ATTENTION	NORMAL	ABNORMAL				
Particles >14µm	ASTM D7647	>80	101	64	<u>▲</u> 542				
Particles >21µm	ASTM D7647	>20	△ 30	18	<u> </u>				
Oil Cleanliness	ISO 4406 (c)	>/17/13	19/17/14	19/17/13	2 0/16				

Customer Id: OFFFRE Sample No.: KCPA007756 Lab Number: 05981912 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:

Don Baldridge +1 don.b505@comcast.net

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

30 Jan 2023 Diag: Doug Bogart

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



08 Apr 2022 Diag: Don Baldridge

150



No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. Moderate concentration of visible dirt/debris present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



26 Mar 2020 Diag: Angela Borella

ISO



The oil change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





OIL ANALYSIS REPORT

Sample Rating Trend



ISO

KAESER BSD 50 5085453 (S/N 1212)

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is a moderate amount of particulates present in the oil.

Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Jan2017 I	eb2018 Jun2018 Apr20	19 Mar2020 Apr2022 Jan2023	Oct2023	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA007756	KCP55402	KCP40950
Sample Date		Client Info		12 Oct 2023	30 Jan 2023	08 Apr 2022
Machine Age	hrs	Client Info		48150	43004	39175
Oil Age	hrs	Client Info		0	3000	3259
Oil Changed		Client Info		N/A	Changed	Changed
Sample Status				ATTENTION	NORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	<1
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	<1
Aluminum	ppm	ASTM D5185m	>10	<1	0	<1
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m	>50	3	6	9
Tin	ppm	ASTM D5185m	>10	0	0	0
Antimony	ppm	ASTM D5185m				
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m	90	3	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	0	0
Magnesium	ppm	ASTM D5185m	90	30	30	14
Calcium	ppm	ASTM D5185m	2	0	0	0
Phosphorus	ppm	ASTM D5185m		4	17	3
Zinc	ppm	ASTM D5185m		47	48	43
Sulfur	ppm	ASTM D5185m		19095	18471	15715
CONTAMINANTS	3	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	<1	<1
Sodium	ppm	ASTM D5185m		16	14	6
Potassium	ppm	ASTM D5185m	>20	5	3	0
Water	%	ASTM D6304	>0.05	0.029	0.029	0.018
ppm Water	ppm	ASTM D6304	>500	298.3	293.8	189.4
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		3619	4336	19535
Particles >6µm		ASTM D7647	>1300	1153	1107	<u>▲</u> 5153
Particles >14μm		ASTM D7647	>80	1 01	64	<u></u> 542
Particles >21µm		ASTM D7647	>20	△ 30	18	△ 128
Particles >38µm		ASTM D7647	>4	2	1	▲ 11
Particles >71μm		ASTM D7647	>3	0	0	2
Oil Cleanliness		ISO 4406 (c)	>/17/13	19/17/14	19/17/13	△ 20/16
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2

0.35



OIL ANALYSIS REPORT



Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

F: