

### **OIL ANALYSIS REPORT**

#### Sample Rating Trend

NORMAL

# KAESER 8487203 (S/N 1401)

Compressor

KAESER SIGMA (OEM) S-460 (--- QTS)

#### DIAGNOSIS

#### Recommendation

Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

#### Contamination

The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil.

#### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

			Jan2023	0ct2023		
SAMPLE INFORM	<b>IATION</b>	method	limit/base	current	history1	history2
Sample Number		Client Info		KC125245	KC99689	
Sample Date		Client Info		04 Oct 2023	30 Jan 2023	
Machine Age	hrs	Client Info		4154	2074	
Oil Age	hrs	Client Info		0	2074	
Oil Changed		Client Info		N/A	Changed	
Sample Status				NORMAL	ATTENTION	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	<1	
Chromium	ppm	ASTM D5185m	>10	0	0	
Nickel	ppm	ASTM D5185m	>3	0	0	
Titanium	ppm	ASTM D5185m	>3	0	0	
Silver	ppm	ASTM D5185m	>2	0	0	
Aluminum	ppm	ASTM D5185m	>10	0	<1	
Lead	ppm	ASTM D5185m	>10	0	0	
Copper	ppm	ASTM D5185m	>50	5	4	
Tin	ppm	ASTM D5185m	>10	0	0	
Vanadium	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	
Barium	ppm	ASTM D5185m	90	3	0	
Molybdenum	ppm	ASTM D5185m		0	0	
Manganese	ppm	ASTM D5185m		0	<1	
Magnesium	ppm	ASTM D5185m	90	25	48	
Calcium	ppm	ASTM D5185m	2	0	<1	
Phosphorus	ppm	ASTM D5185m		1	<1	
Zinc	ppm	ASTM D5185m		26	0	
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	0	
Sodium	ppm	ASTM D5185m		5	14	
Potassium	ppm	ASTM D5185m	>20	6	13	
Water	%	ASTM D6304	>0.05	0.015	0.022	
ppm Water	ppm	ASTM D6304	>500	157.0	223.5	
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		1145	5932	
Particles >6µm		ASTM D7647	>1300	438	<u> </u>	
Particles >14µm		ASTM D7647	>80	20	<b>1</b> 57	
Particles >21µm		ASTM D7647		4	▲ 52	
Particles >38µm		ASTM D7647	>4	1	1	
Particles >71µm		ASTM D7647		0	0	
Oil Cleanliness		ISO 4406 (c)	>/17/13	17/16/11	▲ 20/18/14	
FLUID DEGRADA		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.32	0.30	
	ing NOLI/9	70 HVI D0040		0.52	0.00	



lan30/5

> 52 Abnormal 50 48 () 0€ 46 Base

ۍ تې 44 42

6

f particles (1 ml) 8 48 48 28

10 2k 2 11 Ok an 20/75

Water (KF)

Abnorma 0 LE LE


Abnormal 40 38. Jan30/23

Particle Trend

Viscosity @ 40°C

## **OIL ANALYSIS REPORT**

VISUAL



						<b>,</b>	<b>,</b>
	White Metal	scalar	*Visual	NONE	NONE	NONE	
	Yellow Metal	scalar	*Visual	NONE	NONE	NONE	
	Precipitate	scalar	*Visual	NONE	NONE	NONE	
	Silt	scalar	*Visual	NONE	NONE	NONE	
	Debris	scalar	*Visual	NONE	NONE	NONE	
	Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	
0ct4/23	Appearance	scalar	*Visual	NORML	NORML	NORML	
0	Odor	scalar	*Visual	NORML	NORML	NORML	
	Emulsified Water	scalar	*Visual	>0.05	NEG	NEG	
	Free Water	scalar	*Visual		NEG	NEG	
	FLUID PROPERT	TIES	method	limit/base	current	history1	history2
	Visc @ 40°C	cSt	ASTM D445	46	43.9	43.8	
	SAMPLE IMAGES	S	method	limit/base	current	history1	history2
064/23	Color						no image
	Bottom						no image
	GRAPHS						
	Ferrous Alloys			401 520	Particle Count		20
	10 iron			491,520			1 <sup>26</sup>
	6 - 6 - nickel			122,880	-		-24
	4			30,720			-22
	2-						
°C				7,680 SI Ê			-20 28
	an 30/23			0ct4/23 per 1 ml	-		-18 6
	Since formation Materia	-		1) sa 12 480		<b>V</b>	1999
	Non-ferrous Metal	s		of part			Clean
	8 - copper					<b>x</b>	+20 ISO 4406:1999 Cleanliness Code +16 -114 ISO 400:1999 -114 ISO 400
	6			30		、 · · · · · · · · · · · · · · · · · · ·	-12
	2			8	<b>Serer</b> emal		-10
	0/23			0ct4/23	+		-8
	Jan30/23			5 0 0			
	Viscosity @ 40°C				ہوں 6µ م Acid Number	4μ 21μ	38µ 71µ
_	Abnormal			(B/H0) 0.40	T 19		
2	50 +			0.40	- Base	*****	
	45 - Base			0.30 a 0.20 m W 0.10 V 0.10 V 0.00			
*	40 - Abnormal			- U.20	I		
***************************************	35						
	Jan 30/23			0ct4/23	Jan 30/23		0ct4/23
	Jan			ō	Jar		ő
Laboratory Sample No. Lab Number Unique Number Test Package To discuss this sample report, c	: 05981925 : 10699220 : IND 2 ontact Customer Serve	Received Diagnose Diagnost	l : 17 ( ed : 19 ( ician : Dor 00-237-1369	Oct 2023 Oct 2023 n Baldridge 9.	3	14621 ROBER D/	ADE CITY, FL US 33523 vice Manager
* - Denotes test methods that an Statements of conformity to speci					JCGM 106:2012)		T: F:

Contact/Location: Service Manager - ROBDAD