


PROBLEM SUMMARY




KAESER 8396185 (S/N 2001)

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

We advise that you stop the unit and follow the water drain-off procedure for this component. We recommend an early resample in 500 hours to monitor this condition.

PROBLEMATIC TEST RESULTS										
Sample Status				ABNORMAL	ABNORMAL					
Water	%	ASTM D6304	>0.05	A 0.127	0.009					
ppm Water	ppm	ASTM D6304	>500	A 1270	93.9					
Emulsified Water	scalar	*Visual	>0.05	A 0.2%	NEG					

Customer Id: SMATAM Sample No.: KC125442 Lab Number: 05981930 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Don Baldridge +1 <u>don.b505@comcast.net</u>

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com There are no recommended actions for this sample.

service.

HISTORICAL DIAGNOSIS

12 Apr 2023 Diag: Don Baldridge

ISO

Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. Resample at the next service interval to monitor.All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further





OIL ANALYSIS REPORT





KAESER 8396185 (S/N 2001)

Compressor Fluid

KAESER SIGMA (OEM) S-460 (--- GAL)

DIAGNOSIS

Recommendation

We advise that you stop the unit and follow the water drain-off procedure for this component. We recommend an early resample in 500 hours to monitor this condition.

Wear

All component wear rates are normal.

Contamination

There is a light concentration of water present in the oil. The amount and size of particulates present in the system are acceptable.

Fluid Condition

The AN level is acceptable for this fluid.

SAMPLE INFORM	ATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC125442	KC101053	
Sample Date		Client Info		29 Sep 2023	12 Apr 2023	
Machine Age	hrs	Client Info		5178	3848	
Oil Age	hrs	Client Info		0	3848	
Oil Changed		Client Info		N/A	Changed	
Sample Status				ABNORMAL	ABNORMAL	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	<1	
Chromium	ppm	ASTM D5185m	>10	0	0	
Nickel	ppm	ASTM D5185m	>3	0	0	
Titanium	ppm	ASTM D5185m		0	0	
Silver	ppm	ASTM D5185m	>2	0	0	
Aluminum	ppm	ASTM D5185m	>10	0	0	
Lead	ppm	ASTM D5185m	>10	<1	0	
Copper		ASTM D5185m		8	16	
Tin	ppm	ASTM D5185m	>10	0	0	
Vanadium	ppm	ASTM D5185m	>10	0	0	
	ppm	ASTM D5185m				
Cadmium	ppm	ASTIM DST85m		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	
Barium	ppm	ASTM D5185m	90	3	0	
Molybdenum	ppm	ASTM D5185m		0	0	
Manganese	ppm	ASTM D5185m		0	0	
Magnesium	ppm	ASTM D5185m	90	19	2	
Calcium	ppm	ASTM D5185m	2	0	0	
Phosphorus	ppm	ASTM D5185m		3	2	
Zinc	ppm	ASTM D5185m		29	7	
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	<1	
Sodium	ppm	ASTM D5185m		5	0	
Potassium	ppm	ASTM D5185m	>20	3	<1	
Water	%	ASTM D6304	>0.05	A 0.127	0.009	
ppm Water	ppm	ASTM D6304	>500	1270	93.9	
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		498	17503	
Particles >6µm		ASTM D7647	>1300	95	5 434	
Particles >14µm		ASTM D7647	>80	7	1 76	
Particles >21µm		ASTM D7647	>20	2	A 26	
Particles >38µm		ASTM D7647	>4	0	2	
Particles >71µm		ASTM D7647	>3	0	0	
Oil Cleanliness		ISO 4406 (c)	>/17/13	16/14/10	▲ 21/20/15	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.29	0.26	



Built for a lifetime


Acid Number


0.50


admin


ē

OIL ANALYSIS REPORT









* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Contact/Location: Service Manager - SMATAM