


PROBLEM SUMMARY

Sample Rating Trend




WATER



Area
PALASYN 45
Machine Id
SULLIVAN PALATEK 22HE003292 - ROBERT BOSCH/855 CAMP CREEK
Component
Compressor

COMPONENT CONDITION SUMMARY

▲ Water (KF)



RECOMMENDATION

Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS

Sample Status				ATTENTION	NORMAL	NORMAL
Water	%	ASTM D6304	>0.1	▲ 0.555	---	---
ppm Water	ppm	ASTM D6304	>1000	▲ 5550	---	---
Emulsified Water	scalar	*Visual	>0.1	▲ 0.2%	NEG	NEG

Customer Id: UCCELIMCD
Sample No.: UCS05981958
Lab Number: 05981958
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
Don Baldrige +1
don.b505@comcast.net

To change component or sample information:
Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Fluid	---	---	?	Oil and filter change at the time of sampling has been noted.
Change Filter	---	---	?	Oil and filter change at the time of sampling has been noted.

HISTORICAL DIAGNOSIS

25 May 2023 Diag: Jonathan Hester

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the component. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

[view report](#)



22 Feb 2023 Diag: Jonathan Hester

NORMAL




Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

[view report](#)



Area
PALASYN 45
Machine Id
SULLIVAN PALATEK 22HE003292 - ROBERT BOSCH/855 CAMP CREEK
Component
Compressor



DIAGNOSIS

▲ Recommendation

Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

▲ Contamination

There is a moderate concentration of water present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			UCS05981958	UCS05865733	UCS05799815
Sample Date	Client Info			05 Oct 2023	25 May 2023	22 Feb 2023
Machine Age	hrs	Client Info		4436	2914	1554
Oil Age	hrs	Client Info		4436	2914	1154
Oil Changed	Client Info			Changed	Not Changd	Not Changd
Sample Status				ATTENTION	NORMAL	NORMAL




WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	0
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m		0	0	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>25	<1	<1	0
Lead	ppm	ASTM D5185m	>25	<1	0	0
Copper	ppm	ASTM D5185m	>50	0	2	<1
Tin	ppm	ASTM D5185m	>15	<1	0	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		<1	0	0

ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0.0	0	0	0
Barium	ppm	ASTM D5185m	0.0	281	3	<1
Molybdenum	ppm	ASTM D5185m	0	0	0	0
Manganese	ppm	ASTM D5185m	0	0	<1	0
Magnesium	ppm	ASTM D5185m	0.0	1	3	0
Calcium	ppm	ASTM D5185m	0.0	1	4	0
Phosphorus	ppm	ASTM D5185m	966	5	557	541
Zinc	ppm	ASTM D5185m	0	10	15	0
Sulfur	ppm	ASTM D5185m	1309	682	1260	1567

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	2	3
Sodium	ppm	ASTM D5185m		52	<1	<1
Potassium	ppm	ASTM D5185m	>20	7	<1	0
Water	%	ASTM D6304	>0.1	▲ 0.555	---	---
ppm Water	ppm	ASTM D6304	>1000	▲ 5550	---	---

FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.172	0.11	0.07	0.109


OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	LIGHT
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	▲ 0.2%	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	39.9	44.0	42.1

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : UCS05981958 **Received** : 17 Oct 2023
Lab Number : 05981958 **Diagnosed** : 19 Oct 2023
Unique Number : 10699253 **Diagnostician** : Don Baldrige
Test Package : IND 2 (Additional Tests: KF)

ELITE COMPRESSED AIR SYSTEMS INC

MCDONOUGH, GA
 US 30252
 Contact: RONNY MINNIX
 elitecompressed@gmail.com
 T: (770)898-9594
 F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)