

FUEL REPORT

Sample Rating Trend

NORMAL

KIOTI WX4510HST VW6900112

Diesel Fuel Fluid NOT GIVEN (--- GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. All laboratory tests indicate that this sample meets specifications for No.2 ultra-low-sulfur diesel fuel.

Corrosion

All metal levels are normal indicating no corrosion in the system.

Contaminants

There is a moderate amount of particulates present in the fuel. The water content is negligible. There is no bacteria or fungus (yeast and/or mold) indicated in the sample.

Fuel Condition

Sulfur value derived by ASTM D5453 method for ULSD validation. Sulfur level is acceptable for ULSD specification.

				Oct2023		
SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KT0000657		
Sample Date		Client Info		09 Oct 2023		
Machine Age	hrs	Client Info		496		
Sample Status				NORMAL		
PHYSICAL PROP	ERTIES	method	limit/base	current	history1	history2
Specific Gravity		*ASTM D1298		0.845		
Fuel Color	text	*Visual Screen		Red		
ASTM Color	scalar	*ASTM D1500		L4.0		
Visc @ 40°C	cSt	ASTM D445		2.43		
Pensky-Martens Flash Point	°C	*PMCC Calculated		59		
SULFUR CONTEN	١T	method	limit/base	current	history1	history2
Sulfur	ppm	ASTM D5185m		0		
Sulfur (UVF)	ppm	ASTM D5453		10		
DISTILLATION		method	limit/base	current	history1	history2
Initial Boiling Point	°C	ASTM D86		165		
5% Distillation Point	°C	ASTM D86		190		
10% Distill Point	°C	ASTM D86		200		
15% Distillation Point	°C	ASTM D86		209		
20% Distill Point	°C	ASTM D86		216		
30% Distill Point	°C	ASTM D86		230		
40% Distill Point	°C	ASTM D86		244		
50% Distill Point	°C	ASTM D86		258		
60% Distill Point	°C	ASTM D86		272		
70% Distill Point	°C	ASTM D86		287		
80% Distill Point	°C	ASTM D86		304		
85% Distillation Point	°C	ASTM D86		314		
90% Distill Point	°C	ASTM D86		327		
95% Distillation Point	°C	ASTM D86		344		
Final Boiling Point	°C	ASTM D86		354		
Distillation Residue	%	ASTM D86		1.4		
Distillation Loss	%	ASTM D86		0.7		
IGNITION QUALIT	ΓY	method	limit/base	current	history1	history2
API Gravity		ASTM D7777		36.0		
Cetane Index		ASTM D4737	<40.0	46.1		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	<1.0	0		
Sodium	ppm	ASTM D5185m	<0.1	0		
Potassium	ppm	ASTM D5185m	<0.1	<1		
Water	%	ASTM D6304	< 0.05	0.004		
ppm Water	ppm	ASTM D6304	<500	40.4		
% Gasoline	%	*In-House	<0.50	0.0		
% Biodiesel	%	*In-House	<20.0	0.0		




Î

number of particles (per 1

Water

10

FUEL REPORT



Received

Diagnosed

: 17 Oct 2023

: 01 Nov 2023

Diagnostician : Doug Bogart

RANCHLAND TRACTOR 21277 HWY 49 SAUCIER, MS US 39574 Contact: J. BAKER jbaker620@yahoo.com T: (228)223-1991 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012) F:

Report Id: RANSAU [WUSCAR] 05982155 (Generated: 11/01/2023 22:56:18) Rev: 1

Certificate L2367

Sample No.

Lab Number

Unique Number

: KT0000657

: 05982155

: 10699450

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Test Package : DF-2 (Additional Tests: Screen)

Contact/Location: J. BAKER - RANSAU

Page 2 of 2

no image

no image

lct9/23