

## **PROBLEM SUMMARY**

Sample Rating Trend




Machine Id **082CM12002** 

Component **Turbine** 

**ROYAL PURPLE SYNFILM GT 32 (500 GAL)** 

### **COMPONENT CONDITION SUMMARY**



### RECOMMENDATION

Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS								
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL		
Copper	ppm	ASTM D5185m	>5	<u>^</u> 21	<u>^</u> 24	<u>^</u> 20		

Customer Id: ENTHOU Sample No.: RP0020797 Lab Number: 05982352 Test Package: IND 2

To manage this report scan the QR code

To discuss the diagnosis or test data: Angela Borella +1 800-237-1369 angela.borella@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

### **RECOMMENDED ACTIONS**

There are no recommended actions for this sample.

### HISTORICAL DIAGNOSIS

### 09 Jul 2023 Diag: Don Baldridge

WEAR



We recommend you service the filters on this component. Resample at the next service interval to monitor. The copper level is abnormal. All other component wear rates are normal. There is a high amount of particulates present in the oil. The water content is negligible. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



### 21 Mar 2023 Diag: Jonathan Hester

WEAR



We recommend you service the filters on this component. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample. The copper level is abnormal. All other component wear rates are normal. Moderate concentration of visible dirt/debris present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



### 11 Jan 2023 Diag: Don Baldridge

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





### **OIL ANALYSIS REPORT**

## Sample Rating Trend

## **WEAR**

# 082CM12002

Component

**Turbine** 

### **ROYAL PURPLE SYNFILM GT 32 (500 GAL)**

### **DIAGNOSIS**

### Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

### Contamination

The water content is negligible. The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil.

### **Fluid Condition**


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

Number	Client Info	R	P0020797	RP00
LE INFORMATION	method	limit/base	current	h
	y2005 Apr2006	Jun2008 Feb2011 Dec20	112 Aug2016 Nov2020	0ct2022
	m.In		a. ali l	

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number		Client Info		RP0020797	RP0027354	RP0020767
Sample Date		Client Info		17 Oct 2023	09 Jul 2023	21 Mar 2023
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>15	1	<1	<1
Chromium	ppm	ASTM D5185m	>4	0	0	0
Nickel	ppm	ASTM D5185m	>2	0	0	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>10	0	2	1
Lead	ppm	ASTM D5185m		0	<1	2
Copper	ppm	ASTM D5185m	>5	<u> </u>	<u>^</u> 24	<u>^</u> 20
Tin	ppm	ASTM D5185m	>5	0	<1	<1
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	<1	0
Magnesium	ppm	ASTM D5185m		15	28	85
Calcium	ppm	ASTM D5185m		65	<1	1
Phosphorus	ppm	ASTM D5185m		14	2	10
Zinc	ppm	ASTM D5185m		8	0	1
CONTAMINANTS	<b>3</b>	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	<1	<1	<1
Sodium	ppm	ASTM D5185m		<1	<1	0
Potassium	ppm	ASTM D5185m	>20	0	1	0
Water	%	ASTM D6304	>0.03	0.006	0.028	0.023
ppm Water	ppm	ASTM D6304	>300	68.0	287.2	232.5
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		543	7485	
Particles >6µm		ASTM D7647	>1300	202	<b>△</b> 3161	
Particles >14µm		ASTM D7647	>160	29	<b>△</b> 417	
Particles >21µm		ASTM D7647	>40	10	<u>123</u>	
Particles >38μm		ASTM D7647	>10	1	5	
Particles >71µm		ASTM D7647	>3	0	0	
Oil Cleanliness		ISO 4406 (c)	>/17/14	16/15/12	<b>2</b> 0/19/16	
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.37	0.37	0.38



### **OIL ANALYSIS REPORT**



\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: (281)217-1411

F: (281)385-4327