


016GE14001

Area Cogen 2

Component Turbine

# **PROBLEM SUMMARY**

# Sample Rating Trend ISO



## RECOMMENDATION

We recommend you service the filters on this component. Resample at the next service interval to monitor.

**ROYAL PURPLE SYNFILM GT 32 (500 GAL)** 

PROBLEMATIC TEST RESULTS								
Sample Status		ABNORMAL	ABNORMAL	ABNORMAL				
Particles >6µm	ASTM D7647 >1300	) 🔺 3046	10641					
Particles >14µm	ASTM D7647 >160	<b>A</b> 273	<b>A</b> 395					
Particles >21µm	ASTM D7647 >40	<u> </u>	<b>1</b> 06					
Oil Cleanliness	ISO 4406 (c) >/17	/14 🔺 21/19/15	🔺 23/21/16					

Customer Id: ENTHOU Sample No.: RP0020799 Lab Number: 05982356 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Angela Borella +1 800-237-1369 angela.borella@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS						
Action	Status	Date	Done By	Description		
Change Filter			?	We recommend you service the filters on this component.		

## HISTORICAL DIAGNOSIS



09 Jul 2023 Diag: Don Baldridge

We recommend you service the filters on this component. Resample at the next service interval to monitor.All component wear rates are normal. There is a high amount of particulates present in the oil. The water content is negligible. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

## 21 Mar 2023 Diag: Don Baldridge

VIS DEBRIS



We recommend you service the filters on this component. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.All component wear rates are normal. Moderate concentration of visible dirt/debris present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

10 Oct 2022 Diag: Jonathan Hester

We recommend you service the filters on this component. Resample at the next service interval to monitor.All component wear rates are normal. There is a high amount of particulates present in the oil. The water content is negligible. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.






view report



## **OIL ANALYSIS REPORT**



## ISO

#### Area Cogen 2 Machine Id 016GE14001 Component

## **ROYAL PURPLE SYNFILM GT 32 (500 GAL)**

## DIAGNOSIS

## Recommendation

We recommend you service the filters on this component. Resample at the next service interval to monitor.

## Wear

All component wear rates are normal.

## Contamination

There is a high amount of particulates present in the oil. The water content is negligible.

## Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		RP0020799	RP0027356	RP0020769
Sample Date		Client Info		17 Oct 2023	09 Jul 2023	21 Mar 2023
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>15	0	<1	3
Chromium	ppm	ASTM D5185m	>4	0	0	0
Nickel	ppm	ASTM D5185m	>2	0	0	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>10	0	2	1
Lead	ppm	ASTM D5185m		1	1	<1
Copper	ppm	ASTM D5185m	>5	17	22	30
Tin	ppm	ASTM D5185m	>5	0	<1	<1
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	<1	0
Magnesium	ppm	ASTM D5185m		65	46	76
Calcium	ppm	ASTM D5185m		0	<1	<1
Phosphorus	ppm	ASTM D5185m		30	3	0
Zinc	ppm	ASTM D5185m		0	0	<1
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	<1	1	2
Sodium	ppm	ASTM D5185m		4	1	0
Potassium	ppm	ASTM D5185m	>20	0	1	0
Water	%	ASTM D6304	>0.03	0.012	0.022	0.021
ppm Water	ppm	ASTM D6304	>300	126.0	227.5	214.4
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		16382	50549	
Particles >6µm		ASTM D7647	>1300	<u> </u>	10641	
Particles >14µm		ASTM D7647	>160	<u> </u>	<b>A</b> 395	
Particles >21µm		ASTM D7647	>40	<u> </u>	<b>1</b> 06	
Particles >38µm		ASTM D7647	>10	7	6	
Particles >71µm		ASTM D7647	>3	0	0	
Oil Cleanliness		ISO 4406 (c)	>/17/14	<b>A</b> 21/19/15	▲ 23/21/16	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.37	0.31	0.33



0.60

0.00

1200

1000

80

600 Water (

400

20

38

36

(10°C) 25 (40°C) 25

31

28


2


Water (KF)


Viscosity @ 40°C

(B/HOX E0.3 qu 0.24 Pio 0.1

# **OIL ANALYSIS REPORT**














Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)