


### **PROBLEM SUMMARY**

# KAESER SFC22S 6516541 (S/N 1007)

Compressor

#### KAESER SIGMA (OEM) S-460 (--- GAL)

#### COMPONENT CONDITION SUMMARY



#### RECOMMENDATION

The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TES	ST RESULTS				
Sample Status		4	ABNORMAL	NORMAL	NORMAL
Particles >6µm	ASTM D7647 :	>1300 🔺	5172	323	141
Particles >14µm	ASTM D7647	>80	469	23	22
Particles >21µm	ASTM D7647	>20	125	5	7
Particles >38µm	ASTM D7647	>4	7	0	0
Oil Cleanliness	ISO 4406 (c)	>/17/13 🔺	21/20/16	17/16/12	16/14/12


Customer Id: FLIFRE Sample No.: KC05982400 Lab Number: 05982400 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Angela Borella +1 800-237-1369 angela.borella@wearcheckusa.com

*To change component or sample information:* Customer Service +1 1-800-237-1369 <u>customerservice@wearcheck.com</u>



#### **RECOMMENDED ACTIONS**

There are no recommended actions for this sample.

#### HISTORICAL DIAGNOSIS

#### 18 May 2023 Diag: Angela Borella



Resample at the next service interval to monitor.All component wear rates are normal. The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

# view report


#### 09 Aug 2022 Diag: Jonathan Hester



Re

Resample at the next service interval to monitor.All component wear rates are normal. The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.








Resample at the next service interval to monitor.All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.







## **OIL ANALYSIS REPORT**

# KAESER SFC22S 6516541 (S/N 1007)

**Compressor** Fluid

KAESER SIGMA (OEM) S-460 (--- GAL)

#### DIAGNOSIS

#### Recommendation

The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

#### Wear


All component wear rates are normal.

#### Contamination

There is a high amount of particulates present in the oil.

#### **Fluid Condition**


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC05982400	KC101529	KC85838
Sample Date		Client Info		13 Oct 2023	18 May 2023	09 Aug 2022
Machine Age	hrs	Client Info		42252	39241	33015
Oil Age	hrs	Client Info		0	6000	6000
Oil Changed		Client Info		N/A	Changed	Changed
Sample Status				ABNORMAL	NORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	0
Chromium	ppm	ASTM D5185m	>10	0	<1	0
Nickel	ppm	ASTM D5185m	>3	0	0	<1
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	<1	<1
Aluminum	ppm	ASTM D5185m	>10	0	1	<1
Lead	ppm	ASTM D5185m	>10	0	<1	0
Copper	ppm	ASTM D5185m	>50	4	6	9
Tin	ppm	ASTM D5185m	>10	0	<1	<1
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m	90	0	18	0
Molybdenum		ASTM D5185m	30	0	<1	0
-	ppm	ASTM D5185m		0	<1	0
Manganese Magnesium	ppm	ASTM D5185m	90	37	70	14
Calcium	ppm ppm	ASTM D5185m		0	0	0
Phosphorus		ASTM D5185m	2	۰ <1	0	5
Zinc	ppm	ASTM D5185m		0	21	15
	ppm			U	21	-
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0	<1	<1
Sodium	ppm	ASTM D5185m		15	40	10
Potassium	ppm	ASTM D5185m	>20	1	9	2
Water	%	ASTM D6304	>0.05	0.018	0.012	0.013
ppm Water	ppm	ASTM D6304	>500	182.3	125.9	134.2
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		17546	1230	639
Particles >6µm		ASTM D7647	>1300	<u> </u>	323	141
Particles >14µm		ASTM D7647	>80	<u> </u>	23	22
Particles >21µm		ASTM D7647	>20	🔺 125	5	7
Particles >38µm		ASTM D7647	>4	<u> </u>	0	0
Particles >71µm		ASTM D7647	>3	0	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	<b>A</b> 21/20/16	17/16/12	16/14/12
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.30	0.32	0.30




## **OIL ANALYSIS REPORT**








VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	LIGHT	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERT	IES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	46	44.1	44.5	44.4
SAMPLE IMAGES	S	method	limit/base	current	history1	history2
Color						



Bottom



Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Contact/Location: ? ? - FLIFRE

Page 4 of 4

F: