

# **PROBLEM SUMMARY**

Sample Rating Trend




KAESER 6305486

Component

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

## **COMPONENT CONDITION SUMMARY**



#### RECOMMENDATION

Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS								
Sample Status			ABNORMAL	NORMAL	ABNORMAL			
Particles >6µm	ASTM D7647	>1300	<u> </u>	890	<b>4454</b>			
Particles >14µm	ASTM D7647	>80	<b>A</b> 899	59	<u>▲</u> 277			
Particles >21µm	ASTM D7647	>20	<b>190</b>	11	<b>△</b> 65			
Oil Cleanliness	ISO 4406 (c)	>/17/13	<b>22/21/17</b>	19/17/13	<u> </u>			

Customer Id: BEEAMB Sample No.: KC05982406 Lab Number: 05982406 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Angela Borella +1 800-237-1369 angela.borella@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

#### **RECOMMENDED ACTIONS**

Action	Status	Date	Done By	Description
Change Fluid			?	Oil and filter change at the time of sampling has been noted.
Change Filter			?	Oil and filter change at the time of sampling has been noted.

#### HISTORICAL DIAGNOSIS

#### 16 Jun 2022 Diag: Don Baldridge

#### NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



#### 23 Apr 2021 Diag: Angela Borella

#### ISO



Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

# view report

#### 21 Apr 2020 Diag: Doug Bogart

#### ISO



Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





## **OIL ANALYSIS REPORT**

Sampi



ISO

Machine Id

# **KAESER 6305486**

Component

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

## DIAGNOSIS

#### Recommendation

Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

## Contamination

There is a high amount of particulates present in the oil.


#### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Apr202	0 Apr2021	Jun2022 0	ct2023	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC05982406	KC85765	KC89819
Sample Date		Client Info		06 Oct 2023	16 Jun 2022	23 Apr 2021
Machine Age	hrs	Client Info		13447	9598	7284
Oil Age	hrs	Client Info		0	2300	2500
Oil Changed		Client Info		Changed	Changed	Changed
Sample Status				ABNORMAL	NORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	<1	<1
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	0	<1	0
Lead	ppm	ASTM D5185m	>10	0	0	<1
Copper	ppm	ASTM D5185m	>50	2	1	2
Tin	ppm	ASTM D5185m	>10	0	0	<1
Antimony	ppm	ASTM D5185m				0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	2	12
Barium	ppm	ASTM D5185m	90	0	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	0	<1
Magnesium	ppm	ASTM D5185m	90	50	55	55
Calcium	ppm	ASTM D5185m	2	0	0	0
Phosphorus	ppm	ASTM D5185m		1	4	10
Zinc	ppm	ASTM D5185m		0	5	4
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0	0	0
Sodium	ppm	ASTM D5185m		13	12	17
Potassium	ppm	ASTM D5185m	>20	<1	1	2
Water	%	ASTM D6304	>0.05	0.029	0.025	0.025
ppm Water	ppm	ASTM D6304	>500	297.4	257.6	258.2
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		28715	3558	13734
Particles >6µm		ASTM D7647	>1300	<u> </u>	890	<u>4454</u>
Particles >14μm		ASTM D7647	>80	<u> </u>	59	<b>△</b> 277
Particles >21µm		ASTM D7647	>20	<u> </u>	11	<u></u> ▲ 65
Particles >38μm		ASTM D7647	>4	6	1	1
Particles >71µm		ASTM D7647	>3	0	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u>22/21/17</u>	19/17/13	<b>△</b> 19/15
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.36	0.36	0.319



## **OIL ANALYSIS REPORT**







Certificate L2367

Lab Number **Unique Number** 

Test Package

: 05982406

: 10699701

Diagnosed Diagnostician

: 20 Oct 2023 : Angela Borella AMBRIDGE, PA US 15003

Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.

: IND 2

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: F: