




OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Machine Id
GARDNER DENVER SITE 1 AIR B (S/N S491424)

Component
Air Compressor

Fluid
SHELL CORENA S4 R 68 (--- QTS)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

| method | limit/base | current | history1 | history2 |
|---------------|-------------|--------------------|-------------|-------------|
| Sample Number | Client Info | WC0837875 | WC0731515 | WC0731530 |
| Sample Date | Client Info | 07 Oct 2023 | 31 Jul 2023 | 20 May 2023 |
| Machine Age | hrs | Client Info | 0 | 0 |
| Oil Age | hrs | Client Info | 0 | 0 |
| Oil Changed | Client Info | N/A | N/A | N/A |
| Sample Status | | NORMAL | NORMAL | NORMAL |

WEAR METALS

| method | limit/base | current | history1 | history2 | | |
|----------|------------|-------------|----------|----------|----|----|
| Iron | ppm | ASTM D5185m | >50 | 0 | 2 | 2 |
| Chromium | ppm | ASTM D5185m | >4 | 0 | 0 | <1 |
| Nickel | ppm | ASTM D5185m | >4 | 0 | 0 | <1 |
| Titanium | ppm | ASTM D5185m | | 0 | 0 | 0 |
| Silver | ppm | ASTM D5185m | | 0 | 0 | 0 |
| Aluminum | ppm | ASTM D5185m | >10 | 1 | 2 | <1 |
| Lead | ppm | ASTM D5185m | >20 | 0 | 0 | 0 |
| Copper | ppm | ASTM D5185m | >40 | 1 | <1 | 0 |
| Tin | ppm | ASTM D5185m | >5 | 0 | 0 | 1 |
| Vanadium | ppm | ASTM D5185m | | 0 | 0 | 0 |
| Cadmium | ppm | ASTM D5185m | | 0 | 0 | 0 |

ADDITIVES

| method | limit/base | current | history1 | history2 | | |
|------------|------------|-------------|----------|--------------|-----|-----|
| Boron | ppm | ASTM D5185m | | 0 | 0 | 0 |
| Barium | ppm | ASTM D5185m | | <1 | 0 | 0 |
| Molybdenum | ppm | ASTM D5185m | | 0 | 0 | 0 |
| Manganese | ppm | ASTM D5185m | | 0 | 0 | <1 |
| Magnesium | ppm | ASTM D5185m | | 3 | 0 | 0 |
| Calcium | ppm | ASTM D5185m | | 3 | 0 | 1 |
| Phosphorus | ppm | ASTM D5185m | | 277 | 343 | 798 |
| Zinc | ppm | ASTM D5185m | | 8 | 9 | 0 |
| Sulfur | ppm | ASTM D5185m | | 56 | 91 | 20 |

CONTAMINANTS

| method | limit/base | current | history1 | history2 | | |
|-----------|------------|-------------|----------|----------|----|----|
| Silicon | ppm | ASTM D5185m | >25 | 0 | <1 | <1 |
| Sodium | ppm | ASTM D5185m | | 8 | 2 | 5 |
| Potassium | ppm | ASTM D5185m | >20 | 0 | 0 | 2 |

FLUID CLEANLINESS





| method | limit/base | current | history1 | history2 | |
|-----------------|--------------|-----------|-----------------|----------|---------|
| Particles >4µm | ASTM D7647 | >10000 | 7717 | 3521 | 1357 |
| Particles >6µm | ASTM D7647 | >2500 | 798 | 974 | 183 |
| Particles >14µm | ASTM D7647 | >320 | 29 | 62 | 3 |
| Particles >21µm | ASTM D7647 | >80 | 11 | 14 | 1 |
| Particles >38µm | ASTM D7647 | >20 | 1 | 0 | 0 |
| Particles >71µm | ASTM D7647 | >4 | 0 | 0 | 0 |
| Oil Cleanliness | ISO 4406 (c) | >20/18/15 | 20/17/12 | 19/17/13 | 18/15/9 |

FLUID DEGRADATION

| method | limit/base | current | history1 | history2 | | |
|------------------|------------|------------|----------|-------------|------|------|
| Acid Number (AN) | mg KOH/g | ASTM D8045 | | 0.51 | 0.55 | 1.02 |




OIL ANALYSIS REPORT








| VISUAL | method | limit/base | current | history1 | history2 |
|------------------|--------|------------|---------|----------|----------|
| White Metal | scalar | *Visual | NONE | NONE | LIGHT |
| Yellow Metal | scalar | *Visual | NONE | NONE | NONE |
| Precipitate | scalar | *Visual | NONE | NONE | NONE |
| Silt | scalar | *Visual | NONE | NONE | NONE |
| Debris | scalar | *Visual | NONE | NONE | NONE |
| Sand/Dirt | scalar | *Visual | NONE | NONE | NONE |
| Appearance | scalar | *Visual | NORML | NORML | NORML |
| Odor | scalar | *Visual | NORML | NORML | NORML |
| Emulsified Water | scalar | *Visual | >0.6 | NEG | NEG |
| Free Water | scalar | *Visual | | NEG | NEG |

| FLUID PROPERTIES | method | limit/base | current | history1 | history2 |
|------------------|--------|--------------|-------------|----------|----------|
| Visc @ 40°C | cSt | ASTM D445 68 | 74.9 | 73.9 | 75.5 |

| SAMPLE IMAGES | method | limit/base | current | history1 | history2 |
|---------------|--------|------------|---------|----------|----------|
|---------------|--------|------------|---------|----------|----------|



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0837875 **Received** : 18 Oct 2023
Lab Number : **05982507** **Diagnosed** : 25 Oct 2023
Unique Number : 10699802 **Diagnostician** : Doug Bogart
Test Package : IND 2 (Additional Tests: PRTCOUNT)

HILCORP ENERGY - VANDERBILT
 1421 MOBIL OIL ROAD
 VANDERBILT, TX
 US 77991
 Contact: DEREK HARGRAVE
 dhargrave@hilcorp.com
 T: (361)284-7406
 F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)