




# OIL ANALYSIS REPORT

Sample Rating Trend



**NORMAL**



Machine Id  
**HBKM01BE**  
Component  
**Biogas Engine**  
Fluid  
**SHELL MYSELLA S5 S (--- GAL)**

## DIAGNOSIS

### Recommendation

Resample at the next service interval to monitor. ( Customer Sample Comment: Top Up Amount: 30 GAL )

### Wear

All component wear rates are normal.

### Contamination

There is no indication of any contamination in the oil.

### Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>WC0775430</b>	WC0775433	WC0775335
Sample Date	Client Info		<b>16 Oct 2023</b>	09 Oct 2023	02 Oct 2023
Machine Age	hrs	Client Info	<b>105936</b>	105775	105608
Oil Age	hrs	Client Info	<b>161</b>	0	597
Oil Changed	Client Info		<b>Oil Added</b>	Changed	Oil Added
Sample Status			<b>NORMAL</b>	NORMAL	ABNORMAL

## CONTAMINATION

	method	limit/base	current	history1	history2
Fuel	WC Method	>4.0	<b>&lt;1.0</b>	<1.0	<1.0
Glycol	WC Method		<b>NEG</b>	NEG	NEG

## WEAR METALS

	method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m	>15	<b>0</b>	<1	6
Chromium	ppm	ASTM D5185m	>4	<b>0</b>	0	<1
Nickel	ppm	ASTM D5185m	>2	<b>0</b>	0	<1
Titanium	ppm	ASTM D5185m		<b>0</b>	0	<1
Silver	ppm	ASTM D5185m	>5	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m	>6	<b>2</b>	2	2
Lead	ppm	ASTM D5185m	>9	<b>0</b>	<1	<1
Copper	ppm	ASTM D5185m	>6	<b>0</b>	0	2
Tin	ppm	ASTM D5185m	>4	<b>1</b>	<1	4
Vanadium	ppm	ASTM D5185m		<b>0</b>	0	<1
Cadmium	ppm	ASTM D5185m		<b>0</b>	0	0

## ADDITIVES

	method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m		<b>4</b>	5	1
Barium	ppm	ASTM D5185m		<b>&lt;1</b>	0	0
Molybdenum	ppm	ASTM D5185m		<b>3</b>	5	7
Manganese	ppm	ASTM D5185m		<b>0</b>	0	<1
Magnesium	ppm	ASTM D5185m		<b>24</b>	14	28
Calcium	ppm	ASTM D5185m		<b>1398</b>	1375	1598
Phosphorus	ppm	ASTM D5185m	300	<b>313</b>	301	341
Zinc	ppm	ASTM D5185m		<b>383</b>	372	403
Sulfur	ppm	ASTM D5185m		<b>2752</b>	2785	3073

## CONTAMINANTS

	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m	>181	<b>72</b>	18	▲ 199
Sodium	ppm	ASTM D5185m		<b>0</b>	<1	<1
Potassium	ppm	ASTM D5185m	>20	<b>0</b>	3	<1

## INFRA-RED




	method	limit/base	current	history1	history2	
Soot %	%	*ASTM D7844		<b>0</b>	0	0
Nitration	Abs/cm	*ASTM D7624	>20	<b>4.1</b>	3.0	4.8
Sulfation	Abs/.1mm	*ASTM D7415	>30	<b>18.2</b>	15.8	20.5

## FLUID DEGRADATION

	method	limit/base	current	history1	history2	
Oxidation	Abs/.1mm	*ASTM D7414	>25	<b>11.7</b>	9.9	13.7
Acid Number (AN)	mg KOH/g	ASTM D8045		<b>0.26</b>	0.406	1.14
Base Number (BN)	mg KOH/g	ASTM D2896	5.3	<b>3.78</b>	5.07	4.11











# OIL ANALYSIS REPORT



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2	
Visc @ 100°C	cSt	ASTM D445	13.5	<b>13.3</b>	13.26	13.4

## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : WC0775430 **Received** : 18 Oct 2023  
**Lab Number** : 05982540 **Diagnosed** : 19 Oct 2023  
**Unique Number** : 10699835 **Diagnostician** : Sean Felton  
**Test Package** : MOB 2

**EDL NA Recips-Honeybrook**  
 Honey Brook Powerstation, 481 S. Churchtown Road  
 Narvonn, PA  
 US 17555-9574  
 Contact: Christian Adames  
 Christian.Adames@edlenergy.com  
 T:  
 F:

Certificate L2367  
 To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)