

OIL ANALYSIS REPORT

Sample Rating Trend

ISO



Ryan Macrine Id RYN04 Governor Oil

Component

Reservoir Governor System

CONOCO HYDRAULIC AW ISO 46 (35 GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of silt (particulates < 14 microns in size) present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

-)		22013 Sep20	14 Mar2016 May2017	Jun2018 Sep2019 Jan2021	0ct2022	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0715267	WC0715260	WC0757804
Sample Date		Client Info		17 Oct 2023	01 Jul 2023	01 May 2023
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
CONTAMINATION	٧	method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG	NEG	NEG
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	6	4	4
Chromium	ppm	ASTM D5185m	>10	<1	0	0
Nickel	ppm	ASTM D5185m	>10	<1	<1	<1
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>3	<1	0	0
Lead	ppm	ASTM D5185m	>75	0	0	0
Copper	ppm	ASTM D5185m	>15	<1	<1	<1
Tin	ppm	ASTM D5185m	>55	<1	0	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		20	2	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		<1	0	0
Magnesium	ppm	ASTM D5185m		0	<1	<1
Calcium	ppm	ASTM D5185m		45	50	50
Phosphorus	ppm	ASTM D5185m		340	322	314
Zinc	ppm	ASTM D5185m	3100	413	440	435
Sulfur	ppm	ASTM D5185m		1062	975	861
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>8	0	<1	0
Sodium	ppm	ASTM D5185m		3	0	0
Potassium	ppm	ASTM D5185m	>20	0	0	<1
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>320	<u> </u>	△ 2663	<u></u> 15390
Particles >6µm		ASTM D7647	>80	461	△ 533	<u></u> ▲ 816
Particles >14µm		ASTM D7647	>20	10	4 8	11
Particles >21µm		ASTM D7647	>4	2	1 0	3
Particles >38µm		ASTM D7647	>3	0	0	0
Particles >71µm		ASTM D7647	>3	0	0	0
Oil Cleanliness		ISO 4406 (c)	>15/13/11	<u>^</u> 21/16/10	▲ 19/16/13	<u>\$\text{\Delta}\$ 21/17/11</u>
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.31	0.37	0.34



OIL ANALYSIS REPORT







Certificate L2367

Laboratory

Sample No. Lab Number **Unique Number**

: 05994331 Test Package : PLANT

60

20

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : WC0715267 Recieved : 31 Oct 2023 : 01 Nov 2023 Diagnosed

: 10722691 Diagnostician

Viscosity @ 40°C

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

NORTHWESTERN ENERGY

Acid Number

b 0.40 를 0.20 00.00 PG

: Don Baldridge

6700 RAINBOW DAM RD GREAT FALLS, MT

US 59404

Contact: STANLEY BOGNATZ

Contact/Location: STANLEY BOGNATZ - PPLBUT

srb@mbesi.com T: (570)575-9252

F: (570)227-0014