

PROBLEM SUMMARY

KAESER 7406196


Component

Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

Sample Rating Trend ISO Octobro

COMPONENT CONDITION SUMMARY



RECOMMENDATION

The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST	T RESULTS			
Sample Status			ATTENTION	
Particles >6µm	ASTM D7647	>1300	1437	
Particles >14μm	ASTM D7647	>80	<u> </u>	
Particles >21µm	ASTM D7647	>20	△ 32	
Oil Cleanliness	ISO 4406 (c)	>/17/13	20/18/14	

Customer Id: AMASANCAL Sample No.: KCPA007843 Lab Number: 05994359 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Angela Borella +1 800-237-1369 angela.borella@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS



OIL ANALYSIS REPORT

Sa

Sample Rating Trend



Machine Id

KAESER 7406196

Component

Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

DIAGNOSIS

Recommendation

The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a moderate amount of silt (particulates < 14 microns in size) present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

		0±2023					
SAMPLE INFOR	MATION	method	limit/base	current	history1	history2	
Sample Number		Client Info		KCPA007843			
Sample Date		Client Info		18 Oct 2023			
Machine Age	hrs	Client Info		4991			
Oil Age	hrs	Client Info		0			
Oil Changed		Client Info		N/A			
Sample Status				ATTENTION			
WEAR METALS		method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m	>50	<1			
Chromium	ppm	ASTM D5185m	>10	<1			
Nickel	ppm	ASTM D5185m	>3	0			
Titanium	ppm	ASTM D5185m	>3	0			
Silver	ppm	ASTM D5185m	>2	0			
Aluminum	ppm	ASTM D5185m	>10	<1			
Lead	ppm	ASTM D5185m	>10	0			
Copper	ppm	ASTM D5185m	>50	3			
Tin	ppm	ASTM D5185m	>10	<1			
Vanadium	ppm	ASTM D5185m		0			
Cadmium	ppm	ASTM D5185m		0			
ADDITIVES		method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m	0	0			
Barium	ppm	ASTM D5185m	90	20			
Molybdenum	ppm	ASTM D5185m	0	<1			
Manganese	ppm	ASTM D5185m		<1			
Magnesium	ppm	ASTM D5185m	100	48			
Calcium	ppm	ASTM D5185m	0	<1			
Phosphorus	ppm	ASTM D5185m	0	34			
Zinc	ppm	ASTM D5185m	0	35			
Sulfur	ppm	ASTM D5185m	23500	25089			
CONTAMINANT	S	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m	>25	2			
Sodium	ppm	ASTM D5185m		18			
Potassium	ppm	ASTM D5185m	>20	3			
Water	%	ASTM D6304	>0.05	0.022			
ppm Water	ppm	ASTM D6304	>500	225.6			
FLUID CLEANLI	NESS	method	limit/base	current	history1	history2	
Particles >4µm		ASTM D7647		6002			
Particles >6µm		ASTM D7647	>1300	<u> </u>			
Particles >14µm		ASTM D7647	>80	<u> </u>			
Particles >21µm		ASTM D7647	>20	<u> </u>			
Particles >38µm		ASTM D7647	>4	1			
Particles >71µm		ASTM D7647	>3	0			
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u>^</u> 20/18/14			

FLUID DEGRADATION

Acid Number (AN)

method

mg KOH/g ASTM D8045 1.0

limit/base

history1

current

0.36

history2



OIL ANALYSIS REPORT







Certificate L2367

Sample No. Lab Number **Unique Number**

: KCPA007843 : 10722719

: 05994359

Received Diagnosed

: 31 Oct 2023 : 01 Nov 2023

Diagnostician : Angela Borella

Test Package : IND 2 (Additional Tests: KF, PrtCount) To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

2535 E 3RD ST

SAN BERNARDINO, CA US 92346

Contact: Service Manager

T: F: