

# **PROBLEM SUMMARY**

Sample Rating Trend

ISO


1624546 (S/N 1009)

Component

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

## **COMPONENT CONDITION SUMMARY**



## RECOMMENDATION

The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS									
Sample Status			ABNORMAL	ABNORMAL					
Particles >6µm	ASTM D7647	>1300	<b>△</b> 5267	<u>▲</u> 6112					
Particles >14μm	ASTM D7647	>80	<b>248</b>	<b>△</b> 628					
Particles >21µm	ASTM D7647	>20	<b>48</b>	<b>163</b>					
Oil Cleanliness	ISO 4406 (c)	>/17/13	<b>21/20/15</b>	21/20/16					

Customer Id: PARRAB Sample No.: KC05994381 Lab Number: 05994381 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Angela Borella +1 800-237-1369 angela.borella@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

## **RECOMMENDED ACTIONS**

There are no recommended actions for this sample.

## HISTORICAL DIAGNOSIS

## 23 Feb 2023 Diag: Doug Bogart

## DEGRADATION



We recommend that you drain the oil from the component if this has not already been done. The filter change at the time of sampling has been noted. We recommend an early resample to monitor this condition. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is above the recommended limit. The oil viscosity is higher than normal. Additive levels indicate the addition of a different brand, or type of oil. Confirm oil type.






# **OIL ANALYSIS REPORT**

# 1624546 (S/N 1009)

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)



## **DIAGNOSIS**

## Recommendation

The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

All component wear rates are normal.

## Contamination

There is a high amount of particulates present in the oil.

## **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

			Feb2023	0ct2023		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC05994381	KC05792120	
Sample Date		Client Info		18 Oct 2023	23 Feb 2023	
Machine Age	hrs	Client Info		75805	70505	
Oil Age	hrs	Client Info		0	0	
Oil Changed		Client Info		N/A	N/A	
Sample Status				ABNORMAL	ABNORMAL	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	
Chromium	ppm	ASTM D5185m	>10	<1	0	
Nickel	ppm	ASTM D5185m	>3	0	0	
Titanium	ppm	ASTM D5185m	>3	0	0	
Silver	ppm	ASTM D5185m	>2	0	0	
Aluminum	ppm	ASTM D5185m	>10	<1	<1	
Lead	ppm	ASTM D5185m	>10	0	0	
Copper	ppm	ASTM D5185m	>50	7	5	
Tin	ppm	ASTM D5185m	>10	<1	0	
Vanadium	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVEO	1-1-		11 11 11		1111	1111
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	
Barium	ppm	ASTM D5185m	90	20	0	
Molybdenum	ppm	ASTM D5185m		<1	0	
Manganese	ppm	ASTM D5185m		0	0	
Magnesium	ppm	ASTM D5185m	90	0	0	
Calcium	ppm	ASTM D5185m	2	0	0	
Phosphorus	ppm	ASTM D5185m		41	74	
Zinc	ppm	ASTM D5185m		20	0	
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	<1	
Sodium	ppm	ASTM D5185m		5	<1	
Potassium	ppm	ASTM D5185m	>20	0	<1	
Water	%	ASTM D6304	>0.05	0.006	0.020	
ppm Water	ppm	ASTM D6304	>500	67.8	201.1	
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		19179	18448	
Particles >6µm		ASTM D7647	>1300	<b>5267</b>	<u></u> 6112	
Particles >14µm		ASTM D7647	>80	<b>4</b> 248	<b>△</b> 628	
Particles >21µm		ASTM D7647	>20	<b>48</b>	<u>▲</u> 163	
Particles >38µm		ASTM D7647	>4	1	4	
Particles >71μm		ASTM D7647	>3	0	0	
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u>^</u> 21/20/15	<b>△</b> 21/20/16	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.83	▲ 3.04	
ACIO NUMBEI (AN)	my NOT I/g	70 LINI D0043	U.~	0.03	<u> </u>	



## **OIL ANALYSIS REPORT**





Certificate L2367

Sample No. Lab Number **Unique Number** Test Package

: 05994381

: KC05994381 : 10722741 : IND 2

: 31 Oct 2023 Received Diagnosed

: 01 Nov 2023 : Angela Borella Diagnostician

815 JOHN BECK DOCKINS RD RABUN GAP, GA US 30568

Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: F: