


### **PROBLEM SUMMARY**

# KAESER AS 30T 5243846 (S/N 1101)

**Compressor** Fluid

### KAESER SIGMA (OEM) S-460 (--- QTS)

### COMPONENT CONDITION SUMMARY



### RECOMMENDATION

The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS							
Sample Status			ABNORMAL	ABNORMAL	NORMAL		
Particles >6µm	ASTM D7647	>1300	<b>A</b> 2436	<b>4650</b>	314		
Particles >14µm	ASTM D7647	>80	<u> </u>	<b>A</b> 363	33		
Particles >21µm	ASTM D7647	>20	<u> </u>	<u> </u>	13		
Oil Cleanliness	ISO 4406 (c)	>/17/13	<b>A</b> 20/18/15	🔺 21/19/16	15/12		


Customer Id: DIRCOM Sample No.: KC05994384 Lab Number: 05994384 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Angela Borella +1 800-237-1369 angela.borella@wearcheckusa.com

*To change component or sample information:* Customer Service +1 1-800-237-1369 <u>customerservice@wearcheck.com</u>



### **RECOMMENDED ACTIONS**

There are no recommended actions for this sample.

### **HISTORICAL DIAGNOSIS**

#### 14 Jul 2022 Diag: Jonathan Hester



Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

### 11 May 2021 Diag: Don Baldridge



Resample at the next service interval to monitor.All component wear rates are normal. The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

### 06 May 2020 Diag: Don Baldridge

Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.All component wear rates are normal. There is a moderate amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





view report



### **OIL ANALYSIS REPORT**

## KAESER AS 30T 5243846 (S/N 1101)

Compressor

KAESER SIGMA (OEM) S-460 (--- QTS)

### DIAGNOSIS

### Recommendation

The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

### Wear


All component wear rates are normal.

### Contamination

There is a high amount of particulates present in the oil.

### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.




SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC05994384	KC05623096	KC05261958
Sample Date		Client Info		11 Oct 2023	14 Jul 2022	11 May 2021
Machine Age	hrs	Client Info		44053	35423	27224
Oil Age	hrs	Client Info		0	8199	6227
Oil Changed		Client Info		N/A	Changed	Changed
Sample Status				ABNORMAL	ABNORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	1
Chromium	ppm	ASTM D5185m	>10	<1	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	<1
Aluminum	ppm	ASTM D5185m	>10	<1	<1	0
Lead	ppm	ASTM D5185m	>10	0	0	<1
Copper	ppm	ASTM D5185m		8	6	5
Tin	ppm	ASTM D5185m	>10	<1	0	<1
Antimony	ppm	ASTM D5185m				<1
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
	ppin		11 11 11		-	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	<1
Barium	ppm	ASTM D5185m	90	20	0	0
Molybdenum	ppm	ASTM D5185m		<1	0	0
Manganese	ppm	ASTM D5185m		<1	<1	<1
Magnesium	ppm	ASTM D5185m	90	34	31	38
Calcium	ppm	ASTM D5185m	2	0	0	<1
Phosphorus	ppm	ASTM D5185m		35	<1	5
Zinc	ppm	ASTM D5185m		88	61	18
CONTAMINANTS	3	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0	<1	0
Sodium	ppm	ASTM D5185m		13	8	12
Potassium	ppm	ASTM D5185m	>20	0	0	1
Water	%	ASTM D6304	>0.05	0.018	0.026	0.022
ppm Water	ppm	ASTM D6304	>500	188.1	262.7	227.9
FLUID CLEANLIN	NESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		7769	15313	1124
Particles >6µm		ASTM D7647	>1300	<u> </u>	<b>4650</b>	314
Particles >14µm		ASTM D7647	>80	<u> </u>	<b>A</b> 363	33
Particles >21µm		ASTM D7647	>20	<u> </u>	<u> </u>	13
Particles >38µm		ASTM D7647	>4	6	3	1
Particles >71µm		ASTM D7647	>3	0	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	<b>20/18/15</b>	<b>1</b> 21/19/16	15/12
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.32	0.32	0.333
			2		0.0-	0.000


Page 3 of 4




### Built for a lifetime.

## **OIL ANALYSIS REPORT**








VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERT	IES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	46	44.2	44.0	44.3
SAMPLE IMAGES	S	method	limit/base	current	history1	history2
Color				a.		

Bottom



Report Id: DIRCOM [WUSCAR] 05994384 (Generated: 11/01/2023 19:47:05) Rev: 1

Contact/Location: ? ? - DIRCOM

Page 4 of 4