

PROBLEM SUMMARY

Sample Rating Trend




Machine Id
HT 84

Component **Agitator Gearbox**

PETRO CANADA PURITY FG EP GEAR OIL 220 (--- LTR)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

Resample at the next service interval to monitor.

PROBLEMATIC TE	ST RESULTS				
Sample Status			ATTENTION	ABNORMAL	ATTENTION
Particles >4µm	ASTM D7647	>10000	<u> </u>		<u>△</u> 32105
Oil Cleanliness	ISO 4406 (c)	>20/18/16	21/17/12		22/19/15

Customer Id: KRAMASIOW Sample No.: USP0002927 Lab Number: 05994413 Test Package: IND 2

To manage this report scan the QR code

To discuss the diagnosis or test data: Doug Bogart +1 (800)237-1369 x4016 dougb@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

02 May 2023 Diag: Doug Bogart

VIS DEBRIS



We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample. All component wear rates are normal. Moderate concentration of visible dirt/debris present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



27 Oct 2022 Diag: Doug Bogart

ISO



Resample at the next service interval to monitor. All component wear rates are normal. There is a moderate amount of silt (particulates < 6 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.






OIL ANALYSIS REPORT

Machine Id
HT 84 Component

Agitator Gearbox

PETRO CANADA PURITY FG EP GEAR OIL 220 (-





DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is a moderate amount of silt (particulates < 6 microns in size) present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

_ 220 (LTR)		Oc	2022	May2023 Oct20	23	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		USP0002927	USP248902	USP234451
Sample Date		Client Info		26 Oct 2023	02 May 2023	27 Oct 2022
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				ATTENTION	ABNORMAL	ATTENTION
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>150	6	14	16
Chromium	ppm	ASTM D5185m	>10	<1	0	0
Nickel	ppm	ASTM D5185m	>10	0	0	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m		0	0	<1
Aluminum	ppm	ASTM D5185m	>25	<1	0	<1
Lead	ppm	ASTM D5185m	>100	0	0	0
Copper	ppm	ASTM D5185m	>50	<1	<1	<1
Tin	ppm	ASTM D5185m	>10	<1	0	<1
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	<1
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		125	123	163
Barium	ppm	ASTM D5185m		20	0	0
Molybdenum	ppm	ASTM D5185m		<1	1	2
Manganese	ppm	ASTM D5185m		<1	<1	<1
Magnesium	ppm	ASTM D5185m		0	0	1
Calcium	ppm	ASTM D5185m		2	4	6
Phosphorus	ppm	ASTM D5185m		554	1043	1042
Zinc	ppm	ASTM D5185m		33	25	40
Sulfur	ppm	ASTM D5185m		27406	22243	23046
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon		ASTM D5185m		9	16	19
Sodium	ppm	ASTM D5185m	>50	6	29	7
Potassium		ASTM D5185m	> 20	0	24	6
Water	ppm o/			-		0.019
ppm Water	% ppm	ASTM D6304 ASTM D6304	>0.1	0.007 79.5	0.030 302.5	191.7
FLUID CLEANLIN		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>10000	<u>▲ 11642</u>		▲ 32105
Particles >6µm		ASTM D7647		1082		4629
Particles >14µm		ASTM D7647	>640	38		220
Particles >14µm		ASTM D7647		9		48
•		ASTM D7647	>100	1		1
Particles >38µm Particles >71µm				0		0
		ASTM D7647				
Oil Cleanliness	TICL	ISO 4406 (c)	>20/18/16	<u>21/17/12</u>		<u>22/19/15</u>
FLUID DEGRADA		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.51	0.73	1.62	1.79



OIL ANALYSIS REPORT







Certificate L2367

Sample No. Lab Number **Unique Number**

: USP0002927 : 05994413

: 10722773 Test Package : IND 2

Received : 31 Oct 2023 Diagnosed : 01 Nov 2023 Diagnostician : Doug Bogart 1022 12TH ST

MASON CITY, IA US 50401 Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

F: (641)421-2936

T: