




FUEL REPORT

Sample Rating Trend



ISO



Area
[CP29159]
 Machine Id
T3Y00201 - DELIVERY TRUCK

Component
Diesel Fuel
 Fluid
DIESEL FUEL No. 2 (--- QTS)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. All laboratory tests indicate that this sample meets specifications for No.2 ultra-low-sulfur diesel fuel. Appended normal tests performed at subcontracted ISO 17025 laboratory.

Corrosion

All metal levels are normal indicating no corrosion in the system.

Contaminants

There is a high amount of silt (particulates < 14 microns in size) present in the fuel. The water content is negligible. There is no bacteria or fungus (yeast and/or mold) indicated in the sample.

Fuel Condition

Sulfur value derived by ASTM D5453 method for ULSD validation. Sulfur level is acceptable for ULSD specification.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	WC0863801	WC0863799	WC0863793
Sample Date	Client Info	26 Oct 2023	25 Oct 2023	23 Oct 2023
Machine Age	hrs	0	0	0
Sample Status		ATTENTION	NORMAL	ATTENTION

PHYSICAL PROPERTIES

method	limit/base	current	history1	history2
Specific Gravity	*ASTM D1298	0.838	0.838	0.838
Fuel Color	text	Yellow	Red	Red
ASTM Color	scalar	L3.0	L4.0	L5.0
Visc @ 40°C	cSt	2.4	2.43	2.34
Pensky-Martens Flash Point	°C	58	57	55

SULFUR CONTENT

method	limit/base	current	history1	history2
Sulfur	ppm	0	0	0
Sulfur (UVF)	ppm	11	10	12

DISTILLATION

method	limit/base	current	history1	history2
Initial Boiling Point	°C	161	160	154
5% Distillation Point	°C	185	184	187
10% Distill Point	°C	196	195	196
15% Distillation Point	°C	206	204	205
20% Distill Point	°C	214	213	213
30% Distill Point	°C	230	229	228
40% Distill Point	°C	243	243	243
50% Distill Point	°C	257	257	257
60% Distill Point	°C	271	271	270
70% Distill Point	°C	286	286	286
80% Distill Point	°C	302	303	302
85% Distillation Point	°C	311	312	311
90% Distill Point	°C	323	324	323
95% Distillation Point	°C	339	341	341
Final Boiling Point	°C	350	351	350
Distillation Residue	%	1.4	1.4	1.4
Distillation Loss	%	0.5	0.5	0.9

IGNITION QUALITY






method	limit/base	current	history1	history2
API Gravity	ASTM D7777	37.4	37.4	37.4
Cetane Index	ASTM D4737	48.2	48.3	48.2

CONTAMINANTS

method	limit/base	current	history1	history2
Silicon	ppm	<1	<1	0
Sodium	ppm	2	2	0
Potassium	ppm	<1	<1	2
Water	%	0.002	0.003	0.003
ppm Water	ppm	24.3	31.1	36.1
% Gasoline	%	0.0	0.0	0.0
% Biodiesel	%	0.0	0.0	0.0



FUEL REPORT



FLUID CLEANLINESS	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>2500	▲ 5001	2808	▲ 76997
Particles >6µm	ASTM D7647	>640	▲ 978	696	▲ 37437
Particles >14µm	ASTM D7647	>80	19	37	▲ 4882
Particles >21µm	ASTM D7647	>20	3	7	▲ 1272
Particles >38µm	ASTM D7647	>4	0	1	▲ 32
Particles >71µm	ASTM D7647	>3	0	0	1
Oil Cleanliness	ISO 4406 (c)	>18/16/13	▲ 20/17/11	19/17/12	▲ 23/22/19

HEAVY METALS	method	limit/base	current	history1	history2
Aluminum	ppm	ASTM D5185m <0.1	0	0	1
Nickel	ppm	ASTM D5185m <0.1	<1	<1	0
Lead	ppm	ASTM D5185m <0.1	<1	<1	0
Vanadium	ppm	ASTM D5185m <0.1	0	0	0
Iron	ppm	ASTM D5185m <0.1	0	0	0
Calcium	ppm	ASTM D5185m <0.1	0	0	0
Magnesium	ppm	ASTM D5185m <0.1	0	0	0
Phosphorus	ppm	ASTM D5185m <0.1	0	0	0
Zinc	ppm	ASTM D5185m <0.1	0	0	0

SAMPLE IMAGES



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0863801 **Received** : 31 Oct 2023
Lab Number : 05994828 **Diagnosed** : 28 Nov 2023
Unique Number : 10723188 **Diagnostician** : Doug Bogart
Test Package : DF-2 (Additional Tests: Screen)

CARTER MACHINERY COMPANY INC
 1330 LYNCHBURG TURNPIKE
 SALEM, VA
 US 24153
 Contact: TREVOR KIRSTE
 trevor_kirste@cartermachinery.com
 T:
 F: (540)387-1814

Certificate L2367
 To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)