


COOLANT REPORT

KANSAS/44 Machine Id 20.76L [KANSAS^44] Component

Coolant

CATERPILLAR ELC (13 GAL)





DIAGNOSIS

Recommendation

The fluid is suitable for further service.

Corrosion

All metal levels are normal indicating no corrosion in the cooling system.

Contaminants

There is no indication of any contamination in the coolant.


Coolant Condition

Glycol and nitrite levels are acceptable. The pH level of this fluid is within the acceptable limits.


I3 GAL)		Fel	2022	Mar2023 0ct20	23	
SAMPLE INFORM	//ATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0781202	WC0779838	WC0630441
Sample Date		Client Info		09 Oct 2023	06 Mar 2023	15 Feb 2022
Machine Age	hrs	Client Info		15007	13961	12542
Oil Age	hrs	Client Info		14754	13877	0
Oil Changed		Client Info		Not Changd	N/A	Not Changd
Sample Status				NORMAL	NORMAL	NORMAL
PHYSICAL TEST F	RESULTS	method	limit/base	current	history1	history2
Specific Gravity		*ASTM D1298		1.069	1.067	
рН	Scale 0-14	ASTM D1287		7.33	9.12	7.81
Nitrites	ppm	AP-053:2009		524	412	524
Reserve Alkalinity	Scale 0-20	*ASTM D1121				
Percentage Glycol	%	ASTM D3321		51.0	50.0	52
Freezing Point	°F	ASTM D3321		-38	-35	-43
Total Dissolved Solids				378.5	310.5	396.5
Carboxylate				fail	pass	pass
CORROSION INH	IBITORS	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D6130	0	7	22	20
Phosphorus	ppm	ASTM D6130	0	3	0	<1
Boron	ppm	ASTM D6130	0	0	0	0
Molybdenum	ppm	ASTM D6130	950	692	1184	958
CORROSION		method	limit/base	current	history1	history2
Iron	ppm	ASTM D6130	>15	0	0	<1
Aluminum	ppm	ASTM D6130	>10	0	2	<1
Copper	ppm	ASTM D6130	>10	2	<1	<1
Lead	ppm	ASTM D6130	>10	<1	<1	<1
Tin	ppm	ASTM D6130	>10	<1	0	0
Zinc	ppm	ASTM D6130		<1	<1	<1
CONTAMINANTS	;	method	limit/base	current	history1	history2
Chlorine	ppm	ASTM D6130		13	28	13
CARRIER SALTS		method	limit/base	current	history1	history2
Sodium	ppm	ASTM D6130		4176	6015	3207
Potassium	ppm	ASTM D6130		183	372	548
SCALE POTENTI	AL	method	limit/base	current	history1	history2
Calcium	ppm	ASTM D6130		2	<1	2
Magnesium	ppm	ASTM D6130		1	0	1



COOLANT REPORT









Laboratory Sample No.

Lab Number Unique Number

: WC0781202 : 05994832 : 10723192

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 31 Oct 2023 Diagnosed

: 03 Nov 2023 Diagnostician : Jonathan Hester

Test Package : COOL- (Additional Tests: COOL, ICP) To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

SHERWOOD CONSTRUCTION CO INC

3219 WEST MAY ST WICHITA, KS US 67213

Contact: RANDY ROBERTS randy.roberts@sherwood.net

T: (316)943-6491 F: x: