

# **COOLANT REPORT**

### Sample Rating Trend



# OKLAHOMA/102/EG - SKID STEER Machine Id 53.180L [OKLAHOMA^102^EG - SKID STEER] Component Radiator Coolant





NORMAL

Fluic


### EXTENDED LIFE COOLANT (--- GAL)

DIAGNOSIS	SAMPLE INFORM	MATION	method				history2
Recommendation	Sample Number		Client Info		WC0862660		
The fluid is suitable for further service.	Sample Date		Client Info		23 Oct 2023		
Near	Machine Age	hrs	Client Info		4		
All metal levels are normal indicating no corrosion	Oil Age	hrs	Client Info		4		
in the cooling system.	Oil Changed		Client Info		Not Changd		
Contamination	Sample Status				NORMAL		
There is no indication of any contamination in the collant.	PHYSICAL TEST F	RESULTS	s method	limit/base	current	history1	history2
Fluid Condition	Specific Gravity		*ASTM D1298		1.068		
Blycol and nitrite levels are acceptable. The pH	рН	Scale 0-14	ASTM D1287		8.51		
level of this fluid is within the acceptable limits.	Nitrites	ppm	AP-053:2009		788		
	Reserve Alkalinity	Scale 0-20	*ASTM D1121				
	Percentage Glycol	%	ASTM D3321		50.3		
	Freezing Point	°F	ASTM D3321		-35		
	Total Dissolved Solids				346.0		
	Carboxylate				fail		
	CORROSION INH	IIBITORS	S method	limit/base	current	history1	history2
	Silicon	ppm	ASTM D6130		3		
	Phosphorus	ppm	ASTM D6130		2		
	Boron	ppm	ASTM D6130		0		
	Molybdenum	ppm	ASTM D6130		676		
	CORROSION		method	limit/base	current	history1	history2
	Iron	ppm	ASTM D6130		0		
	Aluminum	ppm	ASTM D6130		2		
	Copper	ppm	ASTM D6130		0		
	Lead	ppm	ASTM D6130		<1		
	Tin	ppm	ASTM D6130		<1		
	Zinc	ppm	ASTM D6130		0		
	CONTAMINANTS	8	method	limit/base	current	history1	history2
	Chlorine	ppm	ASTM D6130		10		
	CARRIER SALTS	3	method	limit/base	current	history1	history2
	Sodium	ppm	ASTM D6130		3799		
	Potassium	ppm	ASTM D6130		123		
	SCALE POTENT	IAL	method	limit/base	current	history1	history2
	Calcium	ppm	ASTM D6130		2		
	Magnesium	ppm	ASTM D6130		-		
	magnoolam	ppm			•		



# **COOLANT REPORT**





Certificate L2367

Submitted By: KEVIN HOHEISEL