


## **PROBLEM SUMMARY**

# KAESER SM 7.5 AIRCENTER 6425685 (S/N 1001)

Compressor

KAESER SIGMA (OEM) FG-460 (--- GAL)

### COMPONENT CONDITION SUMMARY



#### RECOMMENDATION

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

#### **PROBLEMATIC TEST RESULTS** Sample Status ATTENTION ABNORMAL ABNORMAL Particles >6µm ASTM D7647 >1300 **1458** ▲ 2605 ▲ 23996 Particles >14µm ASTM D7647 >80 **A** 86 ▲ 1665 Particles >21µm ASTM D7647 >20 25 16 **A** 306 **Oil Cleanliness** ISO 4406 (c) >--/17/13 A 20/18/14 21/19/14 ▲ 23/22/18


Customer Id: HSWORL Sample No.: KC124453 Lab Number: 05995027 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Don Baldridge +1 don.b505@comcast.net

*To change component or sample information:* Customer Service +1 1-800-237-1369 <u>customerservice@wearcheck.com</u>



#### **RECOMMENDED ACTIONS**

There are no recommended actions for this sample.

#### **HISTORICAL DIAGNOSIS**

#### 28 Mar 2023 Diag: Angela Borella



Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

#### 06 Dec 2022 Diag: Jonathan Hester



We recommend you service the filters on this component. Resample at the next service interval to monitor.All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



view repor

view report



#### 01 Feb 2021 Diag: Doug Bogart

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





### **OIL ANALYSIS REPORT**

## KAESER SM 7.5 AIRCENTER 6425685 (S/N 1001)

**Compressor** Fluid

KAESER SIGMA (OEM) FG-460 (--- GAL)

#### DIAGNOSIS

#### Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

#### Wear


All component wear rates are normal.

#### Contamination

There is a moderate amount of particulates present in the oil.

#### Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.





SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC124453	KC101016	KC106449
Sample Date		Client Info		25 Oct 2023	28 Mar 2023	06 Dec 2022
Machine Age	hrs	Client Info		21133	20529	20518
Oil Age	hrs	Client Info		0	1122	1500
Oil Changed		Client Info		N/A	Changed	Not Changd
Sample Status				ATTENTION	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	13	2	<1
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	<1	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	2	<1	0
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m	>50	<1	2	2
Tin	ppm		>10	0	0	0
Antimony	ppm	ASTM D5185m				
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
	ррш		11 11 11	-		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		<1	0	0
Magnesium	ppm	ASTM D5185m		0	0	0
Calcium	ppm	ASTM D5185m		0	0	0
Phosphorus	ppm	ASTM D5185m	500	151	71	94
Zinc	ppm	ASTM D5185m		100	57	79
CONTAMINANTS	S	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	1	0	0
Sodium	ppm	ASTM D5185m		2	2	0
Potassium	ppm	ASTM D5185m	>20	2	0	0
Water	%	ASTM D6304	>0.05	0.002	0.006	0.005
ppm Water	ppm	ASTM D6304	>500	21.3	63.1	52.3
FLUID CLEANLIN	NESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		6011	15222	61720
Particles >6µm		ASTM D7647	>1300	<u> </u>	<b>A</b> 2605	▲ 23996
Particles >14µm		ASTM D7647	>80	<u> </u>	<b>A</b> 86	<b>1</b> 665
Particles >21µm		ASTM D7647	>20	<u> </u>	16	<b>A</b> 306
Particles >38µm		ASTM D7647	>4	1	1	<b>1</b> 7
Particles >71µm		ASTM D7647	>3	0	0	1
Oil Cleanliness		ISO 4406 (c)	>/17/13	<b>20/18/14</b>	<b>2</b> 1/19/14	▲ 23/22/18
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.5	0.42	0.38	0.42
· · · ·	5 5					




## **OIL ANALYSIS REPORT**








VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	LIGHT
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	46	46.3	45.4	47.1
SAMPLE IMAGES		method	limit/base	current	history1	history2
Color						



Bottom



Contact/Location: ? ? - HSWORL

Page 4 of 4

Report Id: HSWORL [WUSCAR] 05995027 (Generated: 11/02/2023 09:43:42) Rev: 1