


OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Machine Id

KAESER CSD 75T 4601719 (S/N 1064)

Component

Compressor

KAESER SIGMA (OEM) FG-460 (--- LTR)

DIAGNOSIS

Recommendation

Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil.

Fluid Condition

Confirm oil type. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Sep.2013	و اوا			
SAMPLE INFORM	ATION		limit/base	Marzuzi Sepzuzz	biotory d	hiotom/2
	TATION	method	imilibase	current	history1	history2
Sample Number		Client Info		KC111367	KC111349	KC70786
Sample Date		Client Info		11 Oct 2023	21 Mar 2023	21 Sep 2022
Machine Age	hrs	Client Info		48490	45099	42127
Oil Age	hrs	Client Info		3000	2972	3153
Oil Changed		Client Info		Changed	Changed	Changed
Sample Status				NORMAL	NORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	<1
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	<1	0
Titanium	ppm	ASTM D5185m	>3	<1	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	<1	<1	2
Lead	ppm	ASTM D5185m	>10	0	0	<1
Copper	ppm	ASTM D5185m	>50	2	3	<1
Tin	ppm	ASTM D5185m	>10	0	0	<1
Antimony	ppm	ASTM D5185m				
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	0	0
Magnesium	ppm	ASTM D5185m		0	<1	0
Calcium	ppm	ASTM D5185m		0	0	0
Phosphorus	ppm	ASTM D5185m	500	3	487	42
Zinc	ppm	ASTM D5185m		0	0	0
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	2	0
Sodium	ppm	ASTM D5185m		1	<1	<1
Potassium	ppm	ASTM D5185m	>20	1	0	0
Water	%	ASTM D6304	>0.05	0.003	0.009	0.003
ppm Water	ppm	ASTM D6304	>500	26.4	93.2	38.5
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		2541	14671	2583
Particles >6µm		ASTM D7647	>1300	606	564	446
Particles >14µm		ASTM D7647	>80	22	5	32
Particles >21µm		ASTM D7647	>20	6	2	9
Particles >38µm		ASTM D7647	>4	0	0	1
Particles >71µm		ASTM D7647	>3	0	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	19/16/12	21/16/10	19/16/12
FLUID DEGRADA	TION	method	limit/base	current	history1	history2

Acid Number (AN)

mg KOH/g ASTM D8045 1.5


0.87

0.38

0.39



OIL ANALYSIS REPORT







Certificate L2367

Unique Number

: 10723398 Test Package : IND 2

Diagnosed

Diagnostician : Don Baldridge

US 49637

Contact: SERVICE MANAGER

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: F: