


OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



RECYCLED NH3

Component

Refrigeration Compressor

USPI ALT-68 SC (--- GAL)

Recommendation

This is a baseline read-out on the submitted sample.

Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Sep2014 Ju	in2017 Aug2018 Dec	2019 Mar2020 Jul2021 I	May2023	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		USP0002947	USP242923	USP177380
Sample Date		Client Info		30 Oct 2023	04 May 2023	26 Jun 2022
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				NORMAL	NORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>8	0	0	8
Chromium	ppm	ASTM D5185m	>2	0	0	0
Nickel	ppm	ASTM D5185m		0	0	<1
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	1
Aluminum	ppm	ASTM D5185m	>3	0	<1	<1
Lead	ppm	ASTM D5185m	>2	0	0	0
Copper	ppm	ASTM D5185m	>8	0	0	<1
Tin	ppm	ASTM D5185m	>4	0	0	0
Antimony	ppm	ASTM D5185m				
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	<1	0
Magnesium	ppm	ASTM D5185m		0	0	0
Calcium	ppm	ASTM D5185m		0	0	0
Phosphorus	ppm	ASTM D5185m		0	0	0
Zinc	ppm	ASTM D5185m		0	0	0
Sulfur	ppm	ASTM D5185m	50	0	0	43
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	3	4	5
Sodium	ppm	ASTM D5185m		0	0	<1
Potassium	ppm		>20	1	0	0
Water	%	ASTM D6304		0.004	0.005	△ 0.021
ppm Water	ppm	ASTM D6304	>100	36.0	51.2	<u>^</u> 216.4
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4μm		ASTM D7647	>10000	1047	269	<u>▲</u> 71746
Particles >6μm		ASTM D7647	>2500	180	59	4 965
Particles >14μm		ASTM D7647	>320	6	10	52
Particles >21µm		ASTM D7647	>80	3	3	6
Particles >38µm		ASTM D7647	>20	0	0	0
Particles >71μm		ASTM D7647	>4	0	0	0
Oil Cleanliness		ISO 4406 (c)	>20/18/15	17/15/10	15/13/10	<u>23/19/13</u>
FLUID DEGRADA	TION	method	limit/base	current	history1	history2

Contact/Location: ? ? - GEOHAR



OIL ANALYSIS REPORT





Certificate L2367

Laboratory Sample No. Lab Number **Unique Number**

: USP0002947 : 05995050 : 10723410 Test Package : IND 2

: 31 Oct 2023 Received Diagnosed : 01 Nov 2023

Diagnostician : Doug Bogart

GEORGES INC 501 N LIBERTY STREET HARRISONBURG, VA US 22802 Contact:

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: F: