

OIL ANALYSIS REPORT

SAMPLE INFORMATION

NORMAL



QUINSYN PLUS **QUINCY CAI930254 - CRAFT DIE CASTING**

Component

Compressor

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is no indication of any contamination in the component.

Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

Sample Rating Trend								
Ī								
	0ct20.	23						
ethod	limit/base	current						

SAMPLE INFORM	TATION	metnoa	ilmit/base	current	nistory i	nistory2
Sample Number		Client Info		UCZ05995085		
Sample Date		Client Info		24 Oct 2023		
Machine Age	hrs	Client Info		8149		
Oil Age	hrs	Client Info		3800		
Oil Changed		Client Info		Changed		
Sample Status				NORMAL		
WEAD METALO		mathad	limit/bass	our root	historyt	history
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0		
Chromium	ppm	ASTM D5185m	>10	0		
Nickel	ppm	ASTM D5185m		0		
Titanium	ppm	ASTM D5185m		<1		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m	>25	0		
Lead	ppm	ASTM D5185m	>25	0		
Copper	ppm	ASTM D5185m	>50	<1		
Tin	ppm	ASTM D5185m	>15	<1		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m		0		
Molybdenum	ppm	ASTM D5185m		0		
Manganese	ppm	ASTM D5185m		0		
Magnesium	ppm	ASTM D5185m		0		
Calcium	ppm	ASTM D5185m		0		
Phosphorus	ppm	ASTM D5185m		<1		
Zinc	ppm	ASTM D5185m		0		
Sulfur	ppm	ASTM D5185m		0		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	10		
Sodium	ppm	ASTM D5185m		0		
Potassium	ppm	ASTM D5185m	>20	<1		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.39		
VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE		
Yellow Metal	scalar	*Visual	NONE	NONE		
Precipitate	scalar	*Visual	NONE	NONE		
Silt	scalar	*Visual	NONE	NONE		
Debris	scalar	*Visual	NONE	NONE		
Sand/Dirt	scalar	*Visual	NONE	NONE		
Appearance	scalar	*Visual	NORML	NORML		
Odor	scalar	*Visual	NORML	NORML		
Emulsified Water	scalar	*Visual	>0.1	NEG		
Free Water	scalar	*Visual		NEG		
2:01:22\ Pay::1			00	ntact/Leastion	Doobol Doopiles	LICZODCIJD



OIL ANALYSIS REPORT







Certificate L2367

Laboratory Sample No. Lab Number

Test Package : IND 2

: 05995085 Unique Number : 10723445

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : UCZ05995085 Received : 31 Oct 2023

Diagnosed : 01 Nov 2023 Diagnostician : Doug Bogart

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

ZORN COMPRESSOR EQUIPMENT

227 AMBROSIO DR, SUITE A GURNEE, IL

US 60031 Contact: Rachel Pesnikov rachel.pesnikov@zornair.com

T: (847)599-1333 F: x:

Contact/Location: Rachel Pesnikov - UCZORGUR