




Machine Id 7014688 (S/N 1158) Component

Compressor Fluid KAESER SIGMA (OEM) M-460 (--- GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS Sample Status ABNORMAL **ATTENTION** ABNORMAL Particles >6µm ASTM D7647 >1300 3242 **1581** ▲ 8232 Particles >14µm ASTM D7647 >80 **4** 91 ▲ 660 Particles >21µm ASTM D7647 >20 39 18 **1**96 **Oil Cleanliness** ISO 4406 (c) >17/13 **1**9/15 **1**8/14 ▲ 20/17


Customer Id: SCRGRE Sample No.: KCPA003693 Lab Number: 05995594 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Don Baldridge +1 <u>don.b505@comcast.net</u>

To change component or sample information: Customer Service +1 1-800-237-1369 <u>customerservice@wearcheck.com</u>



There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

15 Jul 2023 Diag: Jonathan Hester



No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.All component wear rates are normal. There is a moderate amount of particulates present in the oil. The oil viscosity is higher than normal. The AN level is acceptable for this fluid.

03 Jun 2022 Diag: Doug Bogart

25 Oct 2021 Diag: Doug Bogart

Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. Resample at the next service interval to monitor.All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



view report





Oil and filter change at the time of sampling has been noted. We recommend an early resample in 500 hours to

monitor this condition. We were unable to perform a particle count due to a high concentration of particles present in this sample.All component wear rates are normal. Moderate concentration of visible dirt/debris present in the oil. There is a light concentration of water present in the oil. The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.







OIL ANALYSIS REPORT

SAMPLE INFORMATION method limit/base

Sample Rating Trend

current

history1

historv2

Machine Id 7014688 (S/N 1158) Component

Compressor Fluid KAESER SIGMA (OEM) M-460 (--- GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


SAMPLE INFORM	ATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA003693	KCPA004847	KCP51269
Sample Date		Client Info		23 Oct 2023	15 Jul 2023	03 Jun 2022
Machine Age	hrs	Client Info		22273	20375	13019
Oil Age	hrs	Client Info		0	0	3001
Oil Changed		Client Info		N/A	N/A	Changed
Sample Status				ABNORMAL	ATTENTION	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	2
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	<1	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	<1
Aluminum	ppm	ASTM D5185m	>10	<1	0	<1
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m	>50	12	16	26
Tin	ppm	ASTM D5185m	>10	0	<1	<1
Antimony	ppm	ASTM D5185m				
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	0
Barium	ppm	ASTM D5185m	90	0	0	0
Molybdenum	ppm	ASTM D5185m	0	0	0	<1
Manganese	ppm	ASTM D5185m		0	0	0
Magnesium	ppm	ASTM D5185m	100	2	0	<1
Calcium	ppm	ASTM D5185m	0	1	0	0
Phosphorus	ppm	ASTM D5185m	0	<1	0	0
Zinc	ppm	ASTM D5185m	0	28	0	41
Sulfur	ppm	ASTM D5185m	23500	17242	8589	15784
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	0	<1
Sodium	ppm	ASTM D5185m		<1	0	0
Potassium	ppm	ASTM D5185m	>20	<1	<1	<1
Water	%	ASTM D6304	>0.05	0.005	0.012	0.006
ppm Water	ppm	ASTM D6304	>500	58.6	128.6	67.8
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		12351	5660	31850
Particles >6µm		ASTM D7647	>1300	<u> </u>	<u> </u>	▲ 8232
Particles >14µm		ASTM D7647	>80	<u> </u>	4 91	▲ 660
Particles >21µm		ASTM D7647	>20	<u> </u>	18	1 96
Particles >38µm		ASTM D7647	>4	1	1	9
Particles >71µm		ASTM D7647	>3	0	0	0
Oil Cleanliness		ISO 4406 (c)	>17/13	A 19/15	▲ 18/14	2 0/17
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.0	0.50	0.67	0.67
-F1.1F) David			0	tast/Lasstass N		


Report Id: SCRGRE [WUSCAR] 05995594 (Generated: 11/02/2023 16:51:15) Rev: 1


Contact/Location: MARCELO POSADA - SCRGRE



OIL ANALYSIS REPORT








VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERT	IES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	45	49.7	▲ 59.53	54.33
SAMPLE IMAGES	6	method	limit/base	current	history1	history2
Color						

Bottom



Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Certificate L2367

Contact/Location: MARCELO POSADA - SCRGRE