

PROBLEM SUMMARY




KAESER 7256883

Component

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. Resample at the next service interval to monitor.

PROBLEMATIC TE	ST RESULTS				
Sample Status			ATTENTION	NORMAL	
Particles >6µm	ASTM D7647	>1300	<u>^</u> 2120	1253	
Oil Cleanliness	ISO 4406 (c)	>/17/13	19/18/13	17/11	

Customer Id: LEGGOS Sample No.: KC95972 Lab Number: 05995615 Test Package: IND 2

To manage this report scan the QR code

To discuss the diagnosis or test data:

Don Baldridge +1 don.b505@comcast.net

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS Action Status Date Done By Description Change Fluid -- -- ? Oil and filter change at the time of sampling has been noted. Change Filter -- ? Oil and filter change at the time of sampling has been noted.

HISTORICAL DIAGNOSIS

08 Jun 2021 Diag: Jonathan Hester

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the component. The amount and size of particulates present in the system is acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





OIL ANALYSIS REPORT

Sample Rating Trend

ISO

KAESER 7256883

Component

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

DIAGNOSIS

Recommendation

Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a moderate amount of silt (particulates < 14 microns in size) present in the oil.


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

			Jun2021	May2023		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC95972	KC93245	
Sample Date		Client Info		24 May 2023	08 Jun 2021	
Machine Age	hrs	Client Info		622	132	
Oil Age	hrs	Client Info		622	132	
Oil Changed		Client Info		Changed	Changed	
Sample Status				ATTENTION	NORMAL	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	<1	
Chromium	ppm	ASTM D5185m	>10	0	0	
Nickel	ppm	ASTM D5185m	>3	0	<1	
Titanium	ppm	ASTM D5185m	>3	0	0	
Silver	ppm	ASTM D5185m	>2	0	<1	
Aluminum	ppm	ASTM D5185m	>10	0	<1	
Lead	ppm	ASTM D5185m	>10	0	<1	
Copper	ppm	ASTM D5185m	>50	<1	<1	
Tin	ppm	ASTM D5185m	>10	0	<1	
Antimony	ppm	ASTM D5185m			0	
Vanadium	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	15	
Barium	ppm	ASTM D5185m	90	29	20	
Molybdenum	ppm	ASTM D5185m		0	<1	
Manganese	ppm	ASTM D5185m		<1	<1	
Magnesium	ppm	ASTM D5185m	90	35	26	
Calcium	ppm	ASTM D5185m	2	3	<1	
Phosphorus	ppm	ASTM D5185m		<1	8	
Zinc	ppm	ASTM D5185m		27	15	
CONTAMINANTS)	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	<1	
Sodium	ppm	ASTM D5185m		23	8	
Potassium	ppm	ASTM D5185m	>20	4	3	
Water	%	ASTM D6304	>0.05	0.015	0.028	
ppm Water	ppm	ASTM D6304	>500	155.6	282.9	
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		4519	4185	
Particles >6µm		ASTM D7647	>1300	<u>^</u> 2120	1253	
Particles >14μm		ASTM D7647	>80	58	19	
Particles >21µm		ASTM D7647	>20	18	3	
Particles >38μm		ASTM D7647	>4	4	0	
Particles >71µm		ASTM D7647	>3	0	0	
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u> </u>	17/11	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.22	0.144	



OIL ANALYSIS REPORT







Certificate L2367

Sample No. Lab Number **Unique Number** Test Package

: KC95972 : 05995615

: 10723975 : IND 2

: 01 Nov 2023 Received

Diagnosed : 02 Nov 2023 : Don Baldridge Diagnostician

420 HARRIMAN DR GOSHEN, NY US 10924

Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: F: