


PROBLEM SUMMARY

KAESER SFC 225 6578328 (S/N 1008)

Compressor Fluid

KAESER SIGMA (OEM) S-460 (--- GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS							
Sample Status		ATTENTION	NORMAL	NORMAL			
Particles >6µm	ASTM D7647 >13	00 🔺 1394	368	258			
Particles >14µm	ASTM D7647 >80	A 93	20	19			
Particles >21µm	ASTM D7647 >20	<u> </u>	5	5			
Oil Cleanliness	ISO 4406 (c) >/	17/13 🔺 20/18/14	18/16/11	17/15/11			


Customer Id: PASMEA Sample No.: KC101657 Lab Number: 05995632 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Don Baldridge +1 <u>don.b505@comcast.net</u>

To change component or sample information: Customer Service +1 1-800-237-1369 <u>customerservice@wearcheck.com</u>



RECOMMENDED ACTIONS						
Action	Status	Date	Done By	Description		
Change Fluid			?	Oil and filter change at the time of sampling has been noted.		
Change Filter			?	Oil and filter change at the time of sampling has been noted.		

HISTORICAL DIAGNOSIS



03 May 2023 Diag: Don Baldridge

Resample at the next service interval to monitor.All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

26 Oct 2022 Diag: Don Baldridge

NORMAL



Resample at the next service interval to monitor.All component wear rates are normal. The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

06 Jul 2022 Diag: Angela Borella



The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.All component wear rates are normal. There is a moderate amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



view report

view report



OIL ANALYSIS REPORT

KAESER SFC 225 6578328 (S/N 1008)

Compressor Fluid

KAESER SIGMA (OEM) S-460 (--- GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear


All component wear rates are normal.

Contamination

There is a moderate amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





SAMPLE INFORM		mothed	limit/hoco	May2021 Jan2022 Jul2022	historyd	history
		method	limit/base	current	history1	history2
Sample Number		Client Info		KC101657	KC102774	KC93439
Sample Date		Client Info		24 Oct 2023	03 May 2023	26 Oct 2022
Machine Age	hrs	Client Info		29529	28458	25629
Oil Age	hrs	Client Info		3900	2829	4637
Oil Changed		Client Info		Changed	Not Changd	Changed
Sample Status				ATTENTION	NORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	<1
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	<1	<1	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	<1
Aluminum	ppm	ASTM D5185m	>10	<1	1	1
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m	>50	3	2	9
Tin	ppm	ASTM D5185m	>10	0	<1	<1
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES	le le			-	-	-
ADDITIVE5		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m	90	0	24	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	<1	<1
Magnesium	ppm	ASTM D5185m	90	36	51	23
Calcium	ppm	ASTM D5185m	2	1	0	0
Phosphorus	ppm	ASTM D5185m		<1	0	4
Zinc	ppm	ASTM D5185m		0	0	13
CONTAMINANTS	S	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	2	2	3
Sodium	ppm	ASTM D5185m		13	22	11
Potassium	ppm	ASTM D5185m	>20	2	4	3
Water	%	ASTM D6304	>0.05	0.016	0.015	0.005
ppm Water	ppm	ASTM D6304	>500	166.0	150.9	55.2
FLUID CLEANLIN	NESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		5409	1529	1153
Particles >6µm		ASTM D7647	>1300	🔺 1394	368	258
Particles >14µm		ASTM D7647	>80	<mark>/</mark> 93	20	19
Particles >21µm		ASTM D7647	>20	<u> </u>	5	5
Particles >38μm		ASTM D7647	>4	2	0	0
Particles >71µm		ASTM D7647	>3	0	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	20/18/14	18/16/11	17/15/11
FLUID DEGRAD	ATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.29	0.33	0.28
	ing non ry	, 10 H 100+0	0	0.23	0.00	0.20




Built for a lifetime.


OIL ANALYSIS REPORT













VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERT	IES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	46	44.3	44.2	43.9
SAMPLE IMAGES	S	method	limit/base	current	history1	history2

Color



Bottom



To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Certificate L2367

Contact/Location: Service Manager - PASMEA