

## **OIL ANALYSIS REPORT**

## Sample Rating Trend



# Machine Id KAESER CSD 75 5667433 (S/N 1261)

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

## Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

### Contamination

The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil.

### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Mar2017 May2	017 Aug2017 Nov2017 Apr2	019 Nov2019 Sep2020 Dec2020 Apr	2022 Oct2023	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC110220	KC94690	KC64041
Sample Date		Client Info		26 Oct 2023	18 Apr 2022	20 Dec 2020
Machine Age	hrs	Client Info		14420	11216	8974
Oil Age	hrs	Client Info		3204	600	900
Oil Changed		Client Info		Changed	Not Changd	Not Changd
Sample Status				NORMAL	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	<1	<1
Chromium	ppm	ASTM D5185m	>10	0	0	<1
Nickel	ppm	ASTM D5185m	>3	<1	0	<1
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	<1	<1	<1
Lead	ppm	ASTM D5185m	>10	0	<1	<1
Copper	ppm	ASTM D5185m	>50	9	1	2
Tin	ppm	ASTM D5185m	>10	0	<1	0
Antimony	ppm	ASTM D5185m				2
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m	90	0	5	3
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	<1	0
Magnesium	ppm	ASTM D5185m	90	6	68	66
Calcium	ppm	ASTM D5185m	2	<1	2	2
Phosphorus	ppm	ASTM D5185m		<1	5	3
Zinc	ppm	ASTM D5185m		2	10	15
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	<1	<1
Sodium	ppm	ASTM D5185m	<i>&gt;</i> 20	3	21	22
Potassium	ppm	ASTM D5185m	>20	2	5	25
Water	%	ASTM D6304	>0.05	0.009	0.018	0.016
ppm Water	ppm	ASTM D6304	>500	92.6	188.7	160.9
FLUID CLEANLIN		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		1128		48659
Particles >6µm		ASTM D7647	>1300	411		<b>▲</b> 19768
Particles >14µm		ASTM D7647	>80	18		<u>▲</u> 2287
Particles >21µm		ASTM D7647		5		▲ 607
Particles >38µm		ASTM D7647	>4	0		▲ 19
Particles >71µm		ASTM D7647		0		0
Oil Cleanliness		ISO 4406 (c)	>/17/13	17/16/11		<u>△</u> 21/18
FLUID DEGRADA	TION _	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.43	0.44	0.386
()	59					



## **OIL ANALYSIS REPORT**





Certificate L2367

Sample No. Lab Number **Unique Number** Test Package

: 05995635

: KC110220 : 10723995 : IND 2

: 01 Nov 2023 Received Diagnosed : 02 Nov 2023

: Don Baldridge Diagnostician

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

ROMEOVILLE, IL

US 60446

Contact:

T: F: