




# PROBLEM SUMMARY

Sample Rating Trend




DEGRADATION




Area  
**MISSION BELL [9266]**  
 Machine Id  
**MYCOM COMP 18 - MISSION BELL (S/N 632761)**  
 Component  
**Refrigeration Compressor**  
 Fluid  
**NOT GIVEN (5 GAL)**

## COMPONENT CONDITION SUMMARY

▲ Acid Number



▲ Ferrous Alloys



## RECOMMENDATION

We recommend that you drain the oil from the component if this has not already been done. We recommend an early resample to monitor this condition.

## PROBLEMATIC TEST RESULTS

Sample Status		ABNORMAL	NORMAL	---
Iron	ppm ASTM D5185m >8	▲ 42	8	---
Acid Number (AN)	mg KOH/g ASTM D974	▲ 0.205	0.014	---

Customer Id: SCHLOD  
 Sample No.: WC0851609  
 Lab Number: 05995673  
 Test Package: PLANT



To manage this report scan the QR code

To discuss the diagnosis or test data:  
 Jonathan Hester +1 919-379-4092 x4092  
[jhester@wearcheckusa.com](mailto:jhester@wearcheckusa.com)

To change component or sample information:  
 Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)

## RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Fluid	---	---	?	We recommend that you drain the oil from the component if this has not already been done.
Resample	---	---	?	We recommend an early resample to monitor this condition.

## HISTORICAL DIAGNOSIS

29 Jun 2022 Diag: Doug Bogart

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


view report





# OIL ANALYSIS REPORT

Sample Rating Trend



DEGRADATION



Area  
**MISSION BELL [9266]**  
 Machine Id  
**MYCOM COMP 18 - MISSION BELL (S/N 632761)**  
 Component  
**Refrigeration Compressor**  
 Fluid  
**NOT GIVEN (5 GAL)**

## DIAGNOSIS

### Recommendation

We recommend that you drain the oil from the component if this has not already been done. We recommend an early resample to monitor this condition.

### Wear

The iron level is abnormal. All other component wear rates are normal.

### Contamination

There is no indication of any contamination in the oil.

### Fluid Condition

The AN level is at the top-end of the recommended limit. The oil is no longer serviceable.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>WC0851609</b>	WC0653511	---
Sample Date	Client Info		<b>17 Oct 2023</b>	29 Jun 2022	---
Machine Age	hrs	Client Info	<b>0</b>	0	---
Oil Age	hrs	Client Info	<b>0</b>	0	---
Oil Changed	Client Info		<b>N/A</b>	N/A	---
Sample Status			<b>ABNORMAL</b>	NORMAL	---

## WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >8	<b>▲ 42</b>	8	---
Chromium	ppm	ASTM D5185m >2	<b>&lt;1</b>	0	---
Nickel	ppm	ASTM D5185m	<b>0</b>	0	---
Titanium	ppm	ASTM D5185m	<b>0</b>	0	---
Silver	ppm	ASTM D5185m >2	<b>0</b>	0	---
Aluminum	ppm	ASTM D5185m >3	<b>&lt;1</b>	<1	---
Lead	ppm	ASTM D5185m >2	<b>0</b>	<1	---
Copper	ppm	ASTM D5185m >8	<b>3</b>	<1	---
Tin	ppm	ASTM D5185m >4	<b>3</b>	<1	---
Vanadium	ppm	ASTM D5185m	<b>0</b>	0	---
Cadmium	ppm	ASTM D5185m	<b>0</b>	0	---

## ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	<b>0</b>	0	---
Barium	ppm	ASTM D5185m	<b>0</b>	2	---
Molybdenum	ppm	ASTM D5185m	<b>0</b>	0	---
Manganese	ppm	ASTM D5185m	<b>&lt;1</b>	0	---
Magnesium	ppm	ASTM D5185m	<b>0</b>	<1	---
Calcium	ppm	ASTM D5185m	<b>18</b>	6	---
Phosphorus	ppm	ASTM D5185m	<b>0</b>	9	---
Zinc	ppm	ASTM D5185m	<b>2</b>	2	---
Sulfur	ppm	ASTM D5185m	<b>0</b>	278	---





## CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >15	<b>6</b>	2	---
Sodium	ppm	ASTM D5185m	<b>1</b>	0	---
Potassium	ppm	ASTM D5185m >20	<b>&lt;1</b>	<1	---
Water	%	ASTM D6304 >0.01	<b>0.003</b>	0.001	---
ppm Water	ppm	ASTM D6304 >100	<b>25.4</b>	9.5	---

## FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974	<b>▲ 0.205</b>	0.014	---


# OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	---
Yellow Metal	scalar	*Visual	NONE	NONE	---
Precipitate	scalar	*Visual	NONE	NONE	---
Silt	scalar	*Visual	NONE	NONE	---
Debris	scalar	*Visual	NONE	NONE	---
Sand/Dirt	scalar	*Visual	NONE	NONE	---
Appearance	scalar	*Visual	NORML	NORML	---
Odor	scalar	*Visual	NORML	NORML	---
Emulsified Water	scalar	*Visual	>0.01	NEG	---
Free Water	scalar	*Visual		NEG	---

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	69.3	79.8	---

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : WC0851609 **Received** : 01 Nov 2023  
**Lab Number** : 05995673 **Diagnosed** : 03 Nov 2023  
**Unique Number** : 10724033 **Diagnostician** : Jonathan Hester  
**Test Package** : PLANT

**SCHRADER MECHANICAL**  
 1015 BLACK DIAMOND WAY  
 LODI PROVINCE, CA  
 US 95240  
 Contact: Schrader Mechanical  
 amanda.h@smiwest.com  
 T: (209)369-6888  
 F:

Certificate L2367  
 To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)