




# KAESER SK 15 5059954 (S/N 1650)

Compressor

KAESER SIGMA (OEM) M-460 (--- QTS)

### COMPONENT CONDITION SUMMARY



#### RECOMMENDATION

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

#### **PROBLEMATIC TEST RESULTS** Sample Status NORMAL ABNORMAL ABNORMAL Particles >6µm ASTM D7647 >1300 6847 252 **4409** Particles >14µm ASTM D7647 >80 530 20 **A** 88 ▲ ASTM D7647 >20 3 Particles >21µm 151 28 Particles >38µm ASTM D7647 >4 **6** 0 2 **Oil Cleanliness** 15/11 ▲ 19/14 ISO 4406 (c) >--/17/13 🔺 22/20/16


Customer Id: HARTRE Sample No.: KCPA009348 Lab Number: 05996308 Test Package: IND 2



To manage this report scan the QR code

*To discuss the diagnosis or test data:* Don Baldridge +1 <u>don.b505@comcast.net</u>

*To change component or sample information:* Customer Service +1 1-800-237-1369 <u>customerservice@wearcheck.com</u>



#### **RECOMMENDED ACTIONS**

There are no recommended actions for this sample.

#### **HISTORICAL DIAGNOSIS**

#### 04 Oct 2021 Diag: Doug Bogart



Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. Resample at the next service interval to monitor.All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

#### 18 Oct 2019 Diag: Jonathan Hester



Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



view repor



#### 06 Feb 2018 Diag: Angela Borella



Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.All component wear rates are normal. There is a high amount of particulates present in the oil. The oil viscosity is higher than expected for the fluid specified.





#### Report Id: HARTRE [WUSCAR] 05996308 (Generated: 11/03/2023 16:53:35) Rev: 1



## **OIL ANALYSIS REPORT**

#### Machine Id KAESER SK 15 5059954 (S/N 1650) Component

Compressor Fluid

KAESER SIGMA (OEM) M-460 (--- QTS)

### DIAGNOSIS

#### Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

#### Wear


All component wear rates are normal.

#### Contamination

There is a high amount of particulates present in the oil.

#### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



SAMPLE INFORM	<b>ATION</b>	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA009348	KCP39077	KCP21581
Sample Date		Client Info		26 Oct 2023	04 Oct 2021	18 Oct 2019
Machine Age	hrs	Client Info		31554	15078	9631
Oil Age	hrs	Client Info		0	5000	638
Oil Changed		Client Info		N/A	Changed	Changed
Sample Status				ABNORMAL	NORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	<1	3
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	<1
Aluminum	ppm	ASTM D5185m	>10	0	<1	2
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m	>50	10	5	10
Tin	ppm	ASTM D5185m	>10	0	0	0
Antimony	ppm	ASTM D5185m			0	0
Vanadium	ppm	ASTM D5185m		<1	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	<1
Barium	ppm	ASTM D5185m	90	0	0	0
Molybdenum	ppm	ASTM D5185m	0	0	0	0
Manganese	ppm	ASTM D5185m		0	<1	<1
Magnesium	ppm	ASTM D5185m	100	<1	22	22
Calcium	ppm	ASTM D5185m	0	0	0	1
Phosphorus	ppm	ASTM D5185m	0	0	7	6
Zinc	ppm	ASTM D5185m	0	0	22	7
Sulfur	ppm	ASTM D5185m	23500	15606	16221	15153
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	0	<1
Sodium	ppm	ASTM D5185m		2	6	7
Potassium	ppm	ASTM D5185m	>20	3	0	1
Water	%	ASTM D6304	>0.05	0.006	0.019	0.015
ppm Water	ppm	ASTM D6304	>500	66.3	197.3	159.1
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		21842	1150	42317
Particles >6µm		ASTM D7647		<u> </u>	252	<u> </u>
Particles >14µm		ASTM D7647	>80	<u> </u>	20	<u> </u>
Particles >21µm		ASTM D7647		<u> </u>	3	<u> </u>
Particles >38µm		ASTM D7647	>4	<mark>/</mark> 6	0	2
Particles >71µm		ASTM D7647		1	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	<b>A</b> 22/20/16	15/11	19/14
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	ma KOU/a	<b>ASTM D8045</b>	1.0	0.41	0 364	0.256

Acid Number (AN)


mg KOH/g ASTM D8045 1.0


0.364 0.256 0.41 Contact/Location: Service Manager - HARTRE


Report Id: HARTRE [WUSCAR] 05996308 (Generated: 11/03/2023 16:53:36) Rev: 1



# **OIL ANALYSIS REPORT**








VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	LIGHT	LIGHT	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERT	IES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	45	51.9	48.0	48.2
SAMPLE IMAGES	S	method	limit/base	current	history1	history2
Color				A.		

Bottom



\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Certificate L2367

Contact/Location: Service Manager - HARTRE