

PROBLEM SUMMARY

Sample Rating Trend






FES TYSBER SWING-2

Component

Refrigeration Compressor

USPI ALT-68 SC (--- GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS										
Sample Status			ATTENTION	NORMAL	NORMAL					
Particles >6μm	ASTM D7647	>2500	△ 3027	226	751					
Oil Cleanliness	ISO 4406 (c)	>/18/15	2 1/19/14	17/15/10	18/17/12					

Customer Id: TYSBER01 Sample No.: USP0003017 Lab Number: 05996755 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Doug Bogart +1 (800)237-1369 x4016 dougb@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

02 Aug 2023 Diag: Doug Bogart

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the component. The amount and size of particulates present in the system is acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



10 May 2023 Diag: Doug Bogart

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



09 Feb 2023 Diag: Doug Bogart

NORMAL




Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





OIL ANALYSIS REPORT

Sample Rating Trend



FES TYSBER SWING-2

Component

Refrigeration Compressor

USPI ALT-68 SC (--- GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a moderate amount of silt (particulates < 14 microns in size) present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

2014 Mar2016 Jun2017 Jun2018 Jun2019 Aug/2020 Sep2021 Nov2022									
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2			
Sample Number		Client Info		USP0003017	USP0000665	USP248257			
Sample Date		Client Info		23 Oct 2023	02 Aug 2023	10 May 2023			
Machine Age	hrs	Client Info		56008	54940	53826			
Oil Age	hrs	Client Info		0	0	0			
Oil Changed		Client Info		N/A	N/A	N/A			
Sample Status				ATTENTION	NORMAL	NORMAL			
WEAR METALS		method	limit/base	current	history1	history2			
Iron	ppm	ASTM D5185m	>8	2	1	0			
Chromium	ppm	ASTM D5185m	>2	<1	0	0			
Nickel	ppm	ASTM D5185m		0	0	0			
Titanium	ppm	ASTM D5185m		0	0	0			
Silver	ppm	ASTM D5185m	>2	0	0	0			
Aluminum	ppm	ASTM D5185m	>3	<1	0	1			
Lead	ppm	ASTM D5185m	>2	0	0	0			
Copper	ppm	ASTM D5185m		<1	0	0			
Tin	ppm	ASTM D5185m	>4	0	0	0			
Vanadium	ppm	ASTM D5185m		0	0	0			
Cadmium	ppm	ASTM D5185m		<1	0	0			
ADDITIVES		method	limit/base	current	history1	history2			
Boron	ppm	ASTM D5185m		0	0	0			
Barium	ppm	ASTM D5185m		<1	0	0			
Molybdenum	ppm	ASTM D5185m		0	0	0			
Manganese	ppm	ASTM D5185m		0	0	0			
Magnesium	ppm	ASTM D5185m		0	0	0			
Calcium	ppm	ASTM D5185m		1	0	0			
Phosphorus	ppm	ASTM D5185m		0	0	<1			
Zinc	ppm	ASTM D5185m		0	0	0			
Sulfur	ppm	ASTM D5185m	50	0	15	0			
CONTAMINANTS		method	limit/base	current	history1	history2			
Silicon	ppm	ASTM D5185m	>15	4	3	3			
Sodium	ppm	ASTM D5185m		0	0	0			
Potassium	ppm	ASTM D5185m		1	0	0			
Water	%	ASTM D6304	>0.01	0.004	0.003	0.007			
ppm Water	ppm	ASTM D6304	>100	48.5	27.6	77.1			
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2			
Particles >4µm		ASTM D7647		10486	854	2198			
Particles >6µm		ASTM D7647	>2500	△ 3027	226	751			
Particles >14μm		ASTM D7647	>320	138	7	36			
Particles >21µm		ASTM D7647	>80	25	0	8			
Particles >38μm		ASTM D7647	>20	1	0	0			
Particles >71μm		ASTM D7647	>4	0	0	0			
Oil Cleanliness		ISO 4406 (c)	>/18/15	<u>^</u> 21/19/14	17/15/10	18/17/12			
FLUID DEGRADA	TION	method	limit/base	current	history1	history2			
Acid Number (AN)	mg KOH/g	ASTM D974	0.005	0.014	0.015	0.015			



OIL ANALYSIS REPORT





Certificate L2367

Laboratory Sample No. Lab Number **Unique Number**

: 05996755 : 10725115 Test Package : IND 2

: USP0003017

: 02 Nov 2023 Received : 06 Nov 2023 Diagnosed Diagnostician : Doug Bogart

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012) 110 WEST FREEMAN

Contact: MIKE CISCO

BERRYVILLE, AR

T: (870)423-5556

F: (870)423-1602

US 72616