




# PROBLEM SUMMARY

## Sample Rating Trend

ISO




Machine Id  
**MCQUAY CHILLER D / HARRIS DATA CENTER (S/N STNU100800051)**  
 Component  
**Refrigeration Compressor**  
 Fluid  
**NOT GIVEN (7 GAL)**



## COMPONENT CONDITION SUMMARY

### ▲ Particle Trend



## RECOMMENDATION

No corrective action is recommended at this time.  
 Resample at the next service interval to monitor.

## PROBLEMATIC TEST RESULTS

Sample Status			ATTENTION	NORMAL	NORMAL
Particles >4µm	ASTM D7647	>10000	▲ 11377	---	---
Oil Cleanliness	ISO 4406 (c)	>20/18/15	▲ 21/18/12	---	---

Customer Id: MCQRIC  
 Sample No.: WC0812174  
 Lab Number: 05996793  
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
 Don Baldrige +1  
[don.b505@comcast.net](mailto:don.b505@comcast.net)

To change component or sample information:  
 Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)

## RECOMMENDED ACTIONS

*There are no recommended actions for this sample.*

## HISTORICAL DIAGNOSIS

### 16 Sep 2022 Diag: Doug Bogart

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the component. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



### 26 Sep 2019 Diag: Don Baldrige

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the component. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



### 23 Aug 2018 Diag: Don Baldrige

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the component. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report






# OIL ANALYSIS REPORT

Sample Rating Trend

ISO



Machine Id  
**MCQUAY CHILLER D / HARRIS DATA CENTER (S/N STNU100800051)**  
 Component  
**Refrigeration Compressor**  
 Fluid  
**NOT GIVEN (7 GAL)**



## DIAGNOSIS

### Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

### Contamination

There is a moderate amount of silt (particulates < 14 microns in size) present in the oil.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>WC0812174</b>	WC0487288	WCI2310896
Sample Date	Client Info		<b>20 Oct 2023</b>	16 Sep 2022	26 Sep 2019
Machine Age	hrs	Client Info	<b>0</b>	20410	12680
Oil Age	hrs	Client Info	<b>0</b>	20410	12680
Oil Changed	Client Info		<b>N/A</b>	N/A	Not Changd
Sample Status			<b>ATTENTION</b>	NORMAL	NORMAL

## WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >100	<b>22</b>	23	8
Chromium	ppm	ASTM D5185m >2	<b>&lt;1</b>	0	0
Nickel	ppm	ASTM D5185m	<b>1</b>	2	0
Titanium	ppm	ASTM D5185m	<b>0</b>	0	0
Silver	ppm	ASTM D5185m >2	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m >50	<b>&lt;1</b>	1	<1
Lead	ppm	ASTM D5185m >2	<b>3</b>	3	0
Copper	ppm	ASTM D5185m >100	<b>24</b>	27	28
Tin	ppm	ASTM D5185m >4	<b>1</b>	1	0
Antimony	ppm	ASTM D5185m	<b>---</b>	---	0
Vanadium	ppm	ASTM D5185m	<b>0</b>	0	<1
Cadmium	ppm	ASTM D5185m	<b>&lt;1</b>	0	0

## ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	<b>0</b>	0	0
Barium	ppm	ASTM D5185m	<b>0</b>	0	0
Molybdenum	ppm	ASTM D5185m	<b>0</b>	0	0
Manganese	ppm	ASTM D5185m	<b>&lt;1</b>	1	0
Magnesium	ppm	ASTM D5185m	<b>&lt;1</b>	0	2
Calcium	ppm	ASTM D5185m	<b>&lt;1</b>	0	0
Phosphorus	ppm	ASTM D5185m	<b>0</b>	11	2
Zinc	ppm	ASTM D5185m	<b>31</b>	35	21
Sulfur	ppm	ASTM D5185m	<b>21</b>	103	0

## CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >50	<b>8</b>	9	3
Sodium	ppm	ASTM D5185m	<b>0</b>	<1	3
Potassium	ppm	ASTM D5185m >20	<b>4</b>	4	1
Water	%	ASTM D6304 >0.02	<b>0.015</b>	0.005	0.014
ppm Water	ppm	ASTM D6304 >250	<b>153.0</b>	51.3	145.4

## FLUID CLEANLINESS






	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>10000	<b>▲ 11377</b>	---	---
Particles >6µm	ASTM D7647	>2500	<b>1608</b>	---	---
Particles >14µm	ASTM D7647	>320	<b>27</b>	---	---
Particles >21µm	ASTM D7647	>80	<b>7</b>	---	---
Particles >38µm	ASTM D7647	>20	<b>0</b>	---	---
Particles >71µm	ASTM D7647	>4	<b>0</b>	---	---
Oil Cleanliness	ISO 4406 (c)	>20/18/15	<b>▲ 21/18/12</b>	---	---

## FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974	<b>0.107</b>	0.06	0.060




# OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.02	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	30.0	31.9	31.1

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : WC0812174 **Received** : 02 Nov 2023  
**Lab Number** : 05996793 **Diagnosed** : 04 Nov 2023  
**Unique Number** : 10725153 **Diagnostician** : Don Baldrige  
**Test Package** : IND 2 ( Additional Tests: PrtCount )

**DAIKIN APPLIED-RICHMOND**  
 3524 MAYLAND CT  
 RICHMOND, VA  
 US 23233  
 Contact: GANIS HEISLER  
 ganis.heisler@daikin.com  
 T: (804)747-4822  
 F: (804)747-6686

Certificate L2367  
 To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)