




# OIL ANALYSIS REPORT

Sample Rating Trend

**NORMAL**



Area  
**[SV2307050142/1]**  
 Machine Id  
**MCQUAY CHILLER F / HARRIS DATA CENTER (S/N STNU100800074)**  
 Component  
**Refrigeration Compressor**  
 Fluid  
**NOT GIVEN (7 GAL)**

## DIAGNOSIS

### Recommendation

Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

### Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	<b>WC0812175</b>	WC0487279	WCI2310900
Sample Date	Client Info	<b>19 Oct 2023</b>	16 Sep 2022	25 Sep 2019
Machine Age	hrs	Client Info	<b>0</b>	20270
Oil Age	hrs	Client Info	<b>0</b>	20270
Oil Changed	Client Info	<b>N/A</b>	N/A	Not Changd
Sample Status		<b>NORMAL</b>	NORMAL	NORMAL

## WEAR METALS

method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m >100	<b>33</b>	37	11
Chromium	ppm	ASTM D5185m >2	<b>&lt;1</b>	0	0
Nickel	ppm	ASTM D5185m	<b>2</b>	3	<1
Titanium	ppm	ASTM D5185m	<b>0</b>	0	0
Silver	ppm	ASTM D5185m >2	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m >50	<b>&lt;1</b>	1	1
Lead	ppm	ASTM D5185m >2	<b>3</b>	4	3
Copper	ppm	ASTM D5185m >100	<b>15</b>	18	16
Tin	ppm	ASTM D5185m >4	<b>1</b>	1	1
Antimony	ppm	ASTM D5185m	<b>---</b>	---	2
Vanadium	ppm	ASTM D5185m	<b>0</b>	<1	0
Cadmium	ppm	ASTM D5185m	<b>&lt;1</b>	0	0

## ADDITIVES

method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m	<b>0</b>	<1	<1
Barium	ppm	ASTM D5185m	<b>0</b>	0	0
Molybdenum	ppm	ASTM D5185m	<b>0</b>	0	0
Manganese	ppm	ASTM D5185m	<b>&lt;1</b>	1	0
Magnesium	ppm	ASTM D5185m	<b>0</b>	0	<1
Calcium	ppm	ASTM D5185m	<b>&lt;1</b>	0	0
Phosphorus	ppm	ASTM D5185m	<b>0</b>	12	1
Zinc	ppm	ASTM D5185m	<b>33</b>	42	18
Sulfur	ppm	ASTM D5185m	<b>0</b>	93	7

## CONTAMINANTS

method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m >50	<b>10</b>	10	8
Sodium	ppm	ASTM D5185m	<b>0</b>	1	2
Potassium	ppm	ASTM D5185m >20	<b>5</b>	4	0
Water	%	ASTM D6304 >0.02	<b>0.013</b>	0.003	0.011
ppm Water	ppm	ASTM D6304 >250	<b>133.6</b>	27.8	116.2

## FLUID CLEANLINESS






method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >10000	<b>1861</b>	---	---
Particles >6µm	ASTM D7647 >2500	<b>309</b>	---	---
Particles >14µm	ASTM D7647 >320	<b>13</b>	---	---
Particles >21µm	ASTM D7647 >80	<b>3</b>	---	---
Particles >38µm	ASTM D7647 >20	<b>1</b>	---	---
Particles >71µm	ASTM D7647 >4	<b>0</b>	---	---
Oil Cleanliness	ISO 4406 (c) >20/18/15	<b>18/15/11</b>	---	---

## FLUID DEGRADATION

method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g ASTM D974	<b>0.106</b>	0.092	0.058




# OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.02	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	29.9	31.8	31.1

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : WC0812175 **Received** : 02 Nov 2023  
**Lab Number** : 05996796 **Diagnosed** : 04 Nov 2023  
**Unique Number** : 10725156 **Diagnostician** : Don Baldrige  
**Test Package** : IND 2 ( Additional Tests: PrtCount )

**DAIKIN APPLIED-RICHMOND**  
 3524 MAYLAND CT  
 RICHMOND, VA  
 US 23233  
 Contact: GANIS HEISLER  
 ganis.heisler@daikin.com  
 T: (804)747-4822  
 F: (804)747-6686

Certificate L2367  
 To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)