


## **PROBLEM SUMMARY**

# K-2002 Instrument Air Compressor

Tank Air Compressor Fluid CASTROL Alpha HC 68 (--- GAL)

### COMPONENT CONDITION SUMMARY



### RECOMMENDATION

No corrective action is recommended at this time. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS									
Sample Status			ABNORMAL	ABNORMAL	NORMAL				
Silicon	ppm	ASTM D5185m	>12	<u> </u>	<b>1</b> 5	0			


Customer Id: BPEEND Sample No.: HLC0002314 Lab Number: 05997368 Test Package: IND 2



To manage this report scan the QR code

*To discuss the diagnosis or test data:* Don Baldridge +1 <u>don.b505@comcast.net</u>

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com



### **RECOMMENDED ACTIONS**

There are no recommended actions for this sample.

### **HISTORICAL DIAGNOSIS**

### 10 Jun 2023 Diag: Angela Borella



No corrective action is recommended at this time. Resample at the next service interval to monitor.All component wear rates are normal. Elemental level of silicon (Si) above normal. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

### 06 Dec 2020 Diag: Jonathan Hester



31 Dec 2019 Diag: Doug Bogart



Resample at the next service interval to monitor.All component wear rates are normal. There is no indication of any contamination in the component. The amount and size of particulates present in the system is acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





view report



Resample at the next service interval to monitor.All component wear rates are normal. There is no indication of any contamination in the component. The amount and size of particulates present in the system is acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.









## **OIL ANALYSIS REPORT**

# K-2002 Instrument Air Compressor

Tank Air Compressor Fluid CASTROL Alpha HC 68 (--- GAL)

### DIAGNOSIS

### Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor.

### Wear


All component wear rates are normal.

### Contamination

Elemental level of silicon (Si) above normal indicating ingress of seal material. The amount and size of particulates present in the system are acceptable.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



### SAMPLE INFORMATION method limit/base current history1 history2 HLC0002314 HLC0002685 HLC0000953 Sample Number **Client Info** 06 Dec 2020 Sample Date Client Info 12 Oct 2023 10 Jun 2023 0 0 Machine Age hrs **Client Info** 0 Oil Age hrs Client Info 0 0 0 Oil Changed N/A N/A N/A **Client Info** Sample Status ABNORMAL ABNORMAL NORMAL WEAR METALS method limit/base current history1 history2 >70 0 0 0 Iron ppm ASTM D5185m Chromium ASTM D5185m >15 0 0 ppm <1 Nickel ppm ASTM D5185m >6 0 0 0 Titanium ASTM D5185m 0 0 0 ppm 0 Silver ppm ASTM D5185m 0 0 Aluminum ASTM D5185m >10 1 0 ppm <1 Lead ASTM D5185m >20 0 0 0 ppm ASTM D5185m 0 Copper >80 0 ppm <1 Tin ppm ASTM D5185m >15 0 0 0 Antimony ASTM D5185m 0 ppm ---Vanadium ppm ASTM D5185m 0 0 0 Cadmium ASTM D5185m 0 0 0 ppm **ADDITIVES** method limit/base current historv1 historv2 Boron ppm ASTM D5185m 0 0 <1 Barium ASTM D5185m 0 4 0 ppm Molybdenum ppm ASTM D5185m <1 0 0 0 0 0 Manganese ASTM D5185m ppm 0 0 Magnesium ASTM D5185m <1 ppm 0 Calcium ppm ASTM D5185m 1 1 Phosphorus ASTM D5185m 0 3 4 ppm Zinc ASTM D5185m 0 1 ppm <1 Sulfur ASTM D5185m 228 292 229 ppm CONTAMINANTS method limit/base current history1 history2 Silicon ASTM D5185m >12 21 15 0 ppm Sodium ASTM D5185m 0 ppm <1 1 2 0 Potassium ASTM D5185m >20 <1 ppm **FLUID CLEANLINESS** limit/base current history1 history2 method Particles >4µm ASTM D7647 15238 9164 611 Particles >6µm ASTM D7647 >2500 1273 1135 124 29 Particles >14µm ASTM D7647 >320 11 10 Particles >21µm ASTM D7647 >80 3 6 5 Particles >38µm ASTM D7647 >20 0 0 0 Particles >71µm ASTM D7647 >4 0 0 0 16/14/10 **Oil Cleanliness** 21/17/11 20/17/12 ISO 4406 (c) >--/18/15 **FLUID DEGRADATION** current method limit/base history1 history2

Acid Number (AN) mg KOH/g

ASTM D8045


0.217


0.091


0.044




## **OIL ANALYSIS REPORT**











VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	67.8	70.3	70.5	67.1
SAMPLE IMAGE	S	method	limit/base	current	history1	history2
						Contraction of the
Color						



Bottom





: Don Baldridge

PRUDHOE BAY, AK US 99734 Contact: SEAN LOWTHER slowther@hilcorp.com T: (907)659-6800 F:

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

: 10725728

To discuss this sample report, contact Customer Service at 1-800-237-1369.

Test Package : IND 2 (Additional Tests: PrtCount)

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Diagnostician

Laboratory

Sample No.

Unique Number

Certificate L2367

Contact/Location: SEAN LOWTHER - BPEEND