


PROBLEM SUMMARY

Sample Rating Trend




DEGRADATION



Area
TM 7
Machine Id
TM 7 MACHINE NATURELLE
Component
Hydraulic System
Fluid
NOT GIVEN (--- GAL)

COMPONENT CONDITION SUMMARY

▲ Acid Number



RECOMMENDATION

We recommend that you drain the oil from the component if this has not already been done. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS

Sample Status		ABNORMAL	ABNORMAL	ABNORMAL	
Acid Number (AN)	mg KOH/g	ASTM D8045	▲ 4.57	▲ 4.76	▲ 3.78

Customer Id: KIMMOBTM7
Sample No.: RP0034385
Lab Number: 05997372
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
Don Baldrige +1
don.b505@comcast.net

To change component or sample information:
Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Fluid	---	---	?	We recommend that you drain the oil from the component if this has not already been done.

HISTORICAL DIAGNOSIS

28 Aug 2023 Diag: Doug Bogart

DEGRADATION



We recommend that you drain the oil from the component if this has not already been done. Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is above the recommended limit.

view report



31 May 2023 Diag: Jonathan Hester

DEGRADATION



We recommend that you drain the oil from the component if this has not already been done. Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is above the recommended limit.

view report






OIL ANALYSIS REPORT

Sample Rating Trend

DEGRADATION

Area
TM 7
 Machine Id
TM 7 MACHINE NATURELLE
 Component
Hydraulic System
 Fluid
NOT GIVEN (--- GAL)



DIAGNOSIS

Recommendation

We recommend that you drain the oil from the component if this has not already been done. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

Fluid Condition

The AN level is above the recommended limit.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		RP0034385	RP0034363	RP0034931
Sample Date	Client Info		01 Nov 2023	28 Aug 2023	31 May 2023
Machine Age	hrs	Client Info	0	0	0
Oil Age	hrs	Client Info	0	0	0
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			ABNORMAL	ABNORMAL	ABNORMAL

WEAR METALS

	method	limit/base	current	history1	history2
PQ	ASTM D8184		19	---	15
Iron	ppm	ASTM D5185m >20	2	2	2
Chromium	ppm	ASTM D5185m >20	<1	<1	<1
Nickel	ppm	ASTM D5185m >20	0	0	0
Titanium	ppm	ASTM D5185m	0	0	0
Silver	ppm	ASTM D5185m	0	0	0
Aluminum	ppm	ASTM D5185m >20	<1	4	<1
Lead	ppm	ASTM D5185m >20	<1	0	0
Copper	ppm	ASTM D5185m >20	8	6	6
Tin	ppm	ASTM D5185m >20	1	1	2
Vanadium	ppm	ASTM D5185m	0	0	0
Cadmium	ppm	ASTM D5185m	<1	0	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0
Barium	ppm	ASTM D5185m	0	0	0
Molybdenum	ppm	ASTM D5185m	0	0	0
Manganese	ppm	ASTM D5185m	0	0	<1
Magnesium	ppm	ASTM D5185m	2	3	1
Calcium	ppm	ASTM D5185m	5	3	4
Phosphorus	ppm	ASTM D5185m	148	182	175
Zinc	ppm	ASTM D5185m	34	25	31

CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >15	<1	0	0
Sodium	ppm	ASTM D5185m	0	0	<1
Potassium	ppm	ASTM D5185m >20	2	0	1
Water	%	ASTM D6304 >0.05	0.051	0.068	0.046
ppm Water	ppm	ASTM D6304 >500	516.7	685.1	468.5





FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>5000	80	463	400
Particles >6µm	ASTM D7647	>1300	32	111	95
Particles >14µm	ASTM D7647	>160	6	12	11
Particles >21µm	ASTM D7647	>40	1	5	4
Particles >38µm	ASTM D7647	>10	0	1	0
Particles >71µm	ASTM D7647	>3	0	0	0
Oil Cleanliness	ISO 4406 (c)	>19/17/14	13/12/10	16/14/11	16/14/11

FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	▲ 4.57	▲ 4.76	▲ 3.78


OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	LIGHT
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	48.2	48.0	47.5

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : RP0034385 **Received** : 02 Nov 2023
Lab Number : 05997372 **Diagnosed** : 07 Nov 2023
Unique Number : 10725732 **Diagnostician** : Don Baldrige
Test Package : IND 2 (Additional Tests: PQ)

Kimberly-Clark - Mobile - TM 7
 200 BAYBRIDGE RD
 MOBILE, AL
 US 36610
 Contact: BRAD SNOW
 brad.snow@kcc.com
 T:
 F: (251)452-6335

Certificate L2367
 To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)