


PROBLEM SUMMARY

KAESER BSD 60 6455446 (S/N 1300)

Compressor

KAESER SIGMA (OEM) FG-460 (--- QTS)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.

PROBLEMATIC TEST RESULTS								
Sample Status				ABNORMAL	MARGINAL	MARGINAL		
Aluminum	ppm	ASTM D5185m	>10	<u> </u>	1 5	<u> </u>		
Debris	scalar	*Visual	NONE	🔺 MODER	LIGHT	LIGHT		


Customer Id: DAIDAL Sample No.: KC125201 Lab Number: 05997406 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Don Baldridge +1 don.b505@comcast.net

To change component or sample information: Customer Service +1 1-800-237-1369 <u>customerservice@wearcheck.com</u>



RECOMMENDED ACTIONS						
Action	Status	Date	Done By			
Alert			?			

Description

We were unable to perform a particle count due to a high concentration of particles present in this sample.

HISTORICAL DIAGNOSIS



18 Jan 2023 Diag: Angela Borella

Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. The aluminum level has decreased, but is still abnormal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



view report

23 May 2022 Diag: Jonathan Hester

WEAR



Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. The aluminum level has decreased, but is still abnormal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. The aluminum level is abnormal. All other component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.







OIL ANALYSIS REPORT

KAESER BSD 60 6455446 (S/N 1300)

Compressor

KAESER SIGMA (OEM) FG-460 (--- QTS)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.

🔺 Wear


The aluminum level is abnormal. All other component wear rates are normal.

Contamination

Moderate concentration of visible dirt/debris present in the oil.

Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC125201	KC96359	KC107292
Sample Date		Client Info		13 Oct 2023	18 Jan 2023	23 May 2022
Machine Age	hrs	Client Info		19753	17824	14993
Oil Age	hrs	Client Info		0	2831	3039
Oil Changed		Client Info		N/A	Changed	Changed
Sample Status				ABNORMAL	MARGINAL	MARGINAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	23	7	6
Chromium	ppm	ASTM D5185m	>10	<1	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	<u> </u>	1 5	1 9
Lead	ppm	ASTM D5185m	>10	0	0	<1
Copper	ppm	ASTM D5185m		2	2	2
Tin	ppm	ASTM D5185m	>10	0	0	<1
Antimony	ppm	ASTM D5185m				
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
	ррш	AO INI DO IOOIII		U	-	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		0	0	1
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	0	<1
Magnesium	ppm	ASTM D5185m		<1	0	2
Calcium	ppm	ASTM D5185m		0	<1	0
Phosphorus	ppm	ASTM D5185m	500	320	219	274
Zinc	ppm	ASTM D5185m		172	116	96
CONTAMINANTS	S	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0	2	0
Sodium	ppm	ASTM D5185m		0	<1	0
Potassium	ppm	ASTM D5185m	>20	2	0	<1
Water	%	ASTM D6304	>0.05	0.011	0.003	0.002
ppm Water	ppm	ASTM D6304	>500	112.3	29.6	20.3
FLUID CLEANLIN	NESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647			2096	3277
Particles >6µm		ASTM D7647	>1300		502	412
Particles >14µm		ASTM D7647	>80		36	26
Particles >21µm		ASTM D7647			12	6
Particles >38µm		ASTM D7647	>4		3	0
Particles >71µm		ASTM D7647			1	0
Oil Cleanliness		ISO 4406 (c)	>/17/13		18/16/12	19/16/12
FLUID DEGRADA		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.5	0.58	0.66	0.96
	iiiy NO⊓/ŷ	AG I IVI D0040	1.0	0.50	0.00	0.50



OIL ANALYSIS REPORT








VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE		LIGHT	LIGHT
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERT	IES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	46	46.9	47.2	46.9
SAMPLE IMAGES	6	method	limit/base	current	history1	history2
Color						



Bottom



Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Certificate L2367

Contact/Location: Service Manager - DAIDAL