


Sample Rating Trend



KAESER 2472003

Compressor Fluid KAESER SIGMA (OEM) M-460 (--- GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS

THOBLEMATIO	201112	.00210				
Sample Status				ATTENTION	ATTENTION	ABNORMAL
Water	%	ASTM D6304	>0.05	A 0.050	0.025	▲ 0.051
ppm Water	ppm	ASTM D6304	>500	6 502.9	254.6	5 15.0
Particles >6µm		ASTM D7647	>1300	🔺 1466	1 461	▲ 3255
Oil Cleanliness		ISO 4406 (c)	>/17/13	A 20/18/13	🔺 20/18/13	🔺 19/15

Customer Id: RIGBUR Sample No.: KCPA000792 Lab Number: 05997414 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Don Baldridge +1 <u>don.b505@comcast.net</u>

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

02 Nov 2022 Diag: Angela Borella



Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.All component wear rates are normal. There is a moderate amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



01 Dec 2021 Diag: Angela Borella



Oil and filter change at the time of sampling has been noted. We recommend an early resample in 500 hours to monitor this condition.All component wear rates are normal. There is a high amount of particulates present in the oil. There is a trace of moisture present in the oil. The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.





OIL ANALYSIS REPORT

Sample Rating Trend WATER

Machine Id **KAESER 2472003** Component

Compressor Fluid KAESER SIGMA (OEM) M-460 (--- GAL)

DIAGNOSIS

Recommendation

The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a moderate amount of silt (particulates < 14 microns in size) present in the oil. There is a trace of moisture present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA000792	KCP47222D	KCP39041
Sample Date		Client Info		13 Oct 2023	02 Nov 2022	01 Dec 2021
Machine Age	hrs	Client Info		36828	36287	35784
Oil Age	hrs	Client Info		0	503	0
Oil Changed		Client Info		N/A	Changed	Changed
Sample Status				ATTENTION	ATTENTION	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	<1	0
Chromium	ppm	ASTM D5185m	>10	<1	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	<1	<1	0
Lead	ppm	ASTM D5185m	>10	0	0	<1
Copper	ppm	ASTM D5185m	>50	2	2	<1
Tin	ppm	ASTM D5185m	>10	0	<1	0
Antimony	ppm	ASTM D5185m				0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	1
Barium	ppm	ASTM D5185m	90	33	0	0
Molybdenum	ppm	ASTM D5185m	0	0	0	0
Manganese	ppm	ASTM D5185m		<1	<1	<1
Magnesium	ppm	ASTM D5185m	100	70	29	0
Calcium	ppm	ASTM D5185m	0	1	0	0
Phosphorus	ppm	ASTM D5185m	0	5	81	285
Zinc	ppm	ASTM D5185m	0	26	33	8
Sulfur	ppm	ASTM D5185m	23500	22110	16855	463
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0	<1	0
Sodium	ppm	ASTM D5185m		1	12	0
Potassium	ppm	ASTM D5185m	>20	3	0	0
Water	%	ASTM D6304	>0.05	<u> </u>	0.025	▲ 0.051
ppm Water	ppm	ASTM D6304	>500	6 502.9	254.6	▲ 515.0
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		6376	7997	16144
Particles >6µm		ASTM D7647	>1300	<u> </u>	1 461	▲ 3255
Particles >14µm		ASTM D7647	>80	75	64	🔺 171
Particles >21µm		ASTM D7647	>20	18	16	4 3
Particles >38µm		ASTM D7647	>4	0	1	2
Particles >71µm		ASTM D7647	>3	0	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	A 20/18/13	2 0/18/13	▲ 19/15
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.0	0.36	0.36	0.268


Report Id: RIGBUR [WUSCAR] 05997414 (Generated: 11/05/2023 10:37:05) Rev: 1


Contact/Location: Service Manager - RIGBUR



Built for a lifetime.

Particle Trend 20 (1 ml) number of particles () 0 0ct13/23 lec.






OIL ANALYSIS REPORT

VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERT	TIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	45	45.0	44.1	43.8
SAMPLE IMAGES	S	method	limit/base	current	history1	history2
Color				•		
Rottom						

Bottom



Contact/Location: Service Manager - RIGBUR