


# Machine Id 6071211 (S/N 1025)

-

COMPRESSORS Built for a lifetime."

Component Compressor Fluid KAESER SIGMA (OEM) M-460 (--- QTS)

# COMPONENT CONDITION SUMMARY



## RECOMMENDATION

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS								
Sample Status			ATTENTION	ATTENTION	ATTENTION			
Particles >6µm	ASTM D7647	>1300	🔺 2258	<b>1</b> 709	<b>1</b> 463			
Particles >14µm	ASTM D7647	>80	🔺 141	61	44			
Particles >21µm	ASTM D7647	>20	<u> </u>	5	5			
Oil Cleanliness	ISO 4406 (c)	>/17/13	<u> </u>	19/18/13	19/18/13			

Customer Id: FORAVO Sample No.: KC121502 Lab Number: 05997418 Test Package: IND 2



To manage this report scan the QR code

*To discuss the diagnosis or test data:* Don Baldridge +1 <u>don.b505@comcast.net</u>

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

### **RECOMMENDED ACTIONS**

There are no recommended actions for this sample.

### HISTORICAL DIAGNOSIS

### 26 Jul 2023 Diag: Angela Borella

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.All component wear rates are normal. There is a moderate amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

### 25 Jan 2023 Diag: Doug Bogart

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.All component wear rates are normal. There is a moderate amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

### 26 Oct 2022 Diag: Don Baldridge

Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. Resample at the next service interval to monitor.All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



view report





# **OIL ANALYSIS REPORT**

# Sample Rating Trend ISO

6071211 (S/N 1025) Component

### Compressor Fluid KAESER SIGMA (OEM) M-460 (--- QTS)

# DIAGNOSIS

## Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

# Wear

All component wear rates are normal.

## Contamination

There is a moderate amount of particulates present in the oil.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	<b>IATION</b>	method	limit/base	current	history1	history2
Sample Number		Client Info		KC121502	KC121307	KC101617
Sample Date		Client Info		25 Oct 2023	26 Jul 2023	25 Jan 2023
Machine Age	hrs	Client Info		14889	14187	12267
Oil Age	hrs	Client Info		0	0	1800
Oil Changed		Client Info		N/A	N/A	Not Changd
Sample Status				ATTENTION	ATTENTION	ATTENTION
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	<1	0
Chromium	ppm	ASTM D5185m	>10	<1	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	<1	<1	0
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m	>50	8	6	1
Tin	ppm	ASTM D5185m	>10	0	0	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	0
Barium	ppm	ASTM D5185m	90	0	0	0
Molybdenum	ppm	ASTM D5185m	0	0	0	0
Manganese	ppm	ASTM D5185m		0	<1	0
Magnesium	ppm	ASTM D5185m	100	<1	0	0
Calcium	ppm	ASTM D5185m	0	0	0	0
Phosphorus	ppm	ASTM D5185m	0	0	<1	4
Zinc	ppm	ASTM D5185m	0	0	0	0
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	4	2	2
Sodium	ppm	ASTM D5185m		0	<1	0
Potassium	ppm	ASTM D5185m	>20	2	0	<1
Water	%	ASTM D6304	>0.05	0.011	0.004	0.009
ppm Water	ppm	ASTM D6304	>500	110.5	40.2	93.4
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		5981	3822	3877
Particles >6µm		ASTM D7647	>1300	<u> </u>	<b>1</b> 709	<b>1</b> 463
Particles >14µm		ASTM D7647	>80	<u> </u>	61	44
Particles >21µm		ASTM D7647	>20	<u> </u>	5	5
Particles >38µm		ASTM D7647	>4	2	1	0
Particles >71µm		ASTM D7647	>3	0	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	<b>A</b> 20/18/14	▲ 19/18/13	▲ 19/18/13
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.0	0.44	0.53	0.57



# **OIL ANALYSIS REPORT**

scalar

scalar

scalar

scalar

scalar

scalar

scalar

scalar

cSt

method

\*Visual

\*Visual

\*Visual

\*Visual

\*Visual

\*Visua \*Visual

\*Visual

method

ASTM D445

method

scalar \*Visual

scalar \*Visual

limit/base

NONE

NONE

NONE

NONE

NONE

NONE

NORML

NORML

>0.05

45

current

NONE

NONE

NONE

NONE


LIGHT


NONE

NORML

NORML

NEG





Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Diagnostician

: Don Baldridge

NEG NEG NEG limit/base curren history history2 47.0 50.8 48.5 limit/base current history1 history2

history1

NONE

NONE

NONE

NONE

NONE

NONE

NORML

NORML

NEG

history2

NONE

NONE

NONE

NONE


NONE

NONE

NORML

NORML

NEG



Contact/Location: Service Manager - FORAVO

US 44012

T:

F:

Contact: Service Manager