




# PROBLEM SUMMARY

Area  
**CHEMLUBE PLUS 10 [16353]**  
 Machine Id  
**KIRK HILL 3 - HYDRA FLOW WEST (S/N FF1696U99085)**  
 Component  
**Compressor**

Sample Rating Trend




## VISCOSITY




### COMPONENT CONDITION SUMMARY

▲ Viscosity @ 40°C



▲ Additives



### RECOMMENDATION

The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

### PROBLEMATIC TEST RESULTS

Sample Status				ATTENTION	NORMAL	NORMAL
Barium	ppm	ASTM D5185m	0.8	▲ 805	0	0
Phosphorus	ppm	ASTM D5185m	409	▲ 0	474	334
Sulfur	ppm	ASTM D5185m	1290	▲ 286	420	441
Visc @ 40°C	cSt	ASTM D445	44.56	▲ 53.9	47.5	46.3

Customer Id: UCMCSS  
 Sample No.: UCH05997441  
 Lab Number: 05997441  
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
 Jonathan Hester +1 919-379-4092 x4092  
[jhester@wearcheckusa.com](mailto:jhester@wearcheckusa.com)

To change component or sample information:  
 Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)

## RECOMMENDED ACTIONS

*There are no recommended actions for this sample.*

## HISTORICAL DIAGNOSIS

### 07 Jun 2023 Diag: Don Baldrige

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



### 25 May 2022 Diag: Don Baldrige

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



### 31 Jan 2022 Diag: Angela Borella

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


view report





# OIL ANALYSIS REPORT

Sample Rating Trend



## VISCOSITY



Area  
**CHEMLUBE PLUS 10 [16353]**  
 Machine Id  
**KIRK HILL 3 - HYDRA FLOW WEST (S/N FF1696U99085)**  
 Component  
**Compressor**

### DIAGNOSIS

#### Recommendation

The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

#### Wear

Moderate concentration of visible metal present. All component wear rates are normal.

#### Contamination

There is no indication of any contamination in the oil.

#### Fluid Condition

The oil viscosity is higher than normal. Additive levels indicate the addition of a different brand, or type of oil. Confirm oil type. The AN level is acceptable for this fluid.

### SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>UCH05997441</b>	UCH05871036	UCH05561955
Sample Date	Client Info		<b>26 Oct 2023</b>	07 Jun 2023	25 May 2022
Machine Age	hrs	Client Info	<b>30927</b>	18412	18316
Oil Age	hrs	Client Info	<b>556</b>	96	3109
Oil Changed	Client Info		<b>Not Chngd</b>	Not Chngd	Changed
Sample Status			<b>ATTENTION</b>	NORMAL	NORMAL

### WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >50	<b>0</b>	0	0
Chromium	ppm	ASTM D5185m >10	<b>&lt;1</b>	0	0
Nickel	ppm	ASTM D5185m	<b>0</b>	0	0
Titanium	ppm	ASTM D5185m	<b>0</b>	0	0
Silver	ppm	ASTM D5185m	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m >25	<b>&lt;1</b>	<1	<1
Lead	ppm	ASTM D5185m >25	<b>0</b>	0	2
Copper	ppm	ASTM D5185m >50	<b>&lt;1</b>	<1	<1
Tin	ppm	ASTM D5185m >15	<b>0</b>	0	1
Antimony	ppm	ASTM D5185m	<b>---</b>	---	---
Vanadium	ppm	ASTM D5185m	<b>0</b>	0	0
Cadmium	ppm	ASTM D5185m	<b>&lt;1</b>	0	0

### ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m 0.1	<b>0</b>	0	1
Barium	ppm	ASTM D5185m 0.8	<b>▲ 805</b>	0	0
Molybdenum	ppm	ASTM D5185m 0	<b>0</b>	0	0
Manganese	ppm	ASTM D5185m 0.9	<b>0</b>	0	0
Magnesium	ppm	ASTM D5185m 0	<b>2</b>	0	0
Calcium	ppm	ASTM D5185m 0	<b>4</b>	0	<1
Phosphorus	ppm	ASTM D5185m 409	<b>▲ 0</b>	474	334
Zinc	ppm	ASTM D5185m 0	<b>5</b>	28	30
Sulfur	ppm	ASTM D5185m 1290	<b>▲ 286</b>	420	441

### CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >25	<b>4</b>	0	2
Sodium	ppm	ASTM D5185m	<b>42</b>	3	3
Potassium	ppm	ASTM D5185m >20	<b>6</b>	0	0

### FLUID DEGRADATION




	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045 0.537	<b>0.48</b>	0.61	0.34

### VISUAL

	method	limit/base	current	history1	history2
White Metal	scalar	*Visual NONE	<b>MODER</b>	NONE	NONE
Yellow Metal	scalar	*Visual NONE	<b>NONE</b>	NONE	NONE
Precipitate	scalar	*Visual NONE	<b>NONE</b>	NONE	NONE
Silt	scalar	*Visual NONE	<b>NONE</b>	NONE	NONE
Debris	scalar	*Visual NONE	<b>NONE</b>	NONE	NONE
Sand/Dirt	scalar	*Visual NONE	<b>NONE</b>	NONE	NONE
Appearance	scalar	*Visual NORML	<b>NORML</b>	NORML	NORML
Odor	scalar	*Visual NORML	<b>NORML</b>	NORML	NORML
Emulsified Water	scalar	*Visual >0.1	<b>NEG</b>	NEG	NEG
Free Water	scalar	*Visual	<b>NEG</b>	NEG	NEG







# OIL ANALYSIS REPORT



FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	44.56 ▲ <b>53.9</b>	47.5	46.3

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					
Bottom					

## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : UCH05997441 **Received** : 02 Nov 2023  
**Lab Number** : **05997441** **Diagnosed** : 07 Nov 2023  
**Unique Number** : 10725801 **Diagnostician** : Jonathan Hester  
**Test Package** : IND 2

**MCSS INC - MACHINERY COMPONENTS**  
 326 E 2ND AVE  
 LA HABRA, CA  
 US 90631  
 Contact: BILL INGHAM  
 mcservice@verizon.net  
 T: (562)694-8888  
 F: (562)690-8946

Certificate L2367  
 To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)