




# PROBLEM SUMMARY


Sample Rating Trend



Area  
**Preparation-Prep EB CALENDAR**  
 Machine Id  
**[Preparation-Prep EB CALENDAR] 360014005 - EB CALENDAR MAIN HYD UNIT**  
 Component  
**Hydraulic System**  
 Fluid  
**SHELL TELLUS S2 MX 46 (100 LTR)**

## COMPONENT CONDITION SUMMARY

▲ Particle Trend



## RECOMMENDATION

We recommend you service the filters on this component. Resample at the next service interval to monitor.

## PROBLEMATIC TEST RESULTS

Sample Status			ABNORMAL	ABNORMAL	ABNORMAL
Particles >4µm	ASTM D7647	>5000	▲ 12460	▲ 18190	▲ 163143
Particles >6µm	ASTM D7647	>1300	▲ 2948	▲ 3737	▲ 66700
Particles >14µm	ASTM D7647	>160	▲ 265	▲ 187	130
Particles >21µm	ASTM D7647	>40	▲ 57	36	17
Oil Cleanliness	ISO 4406 (c)	>19/17/14	▲ 21/19/15	▲ 21/19/15	▲ 25/23/14

Customer Id: MICAND  
 Sample No.: TLC0001118  
 Lab Number: 05997913  
 Test Package: PLANT



To manage this report scan the QR code

To discuss the diagnosis or test data:  
 Don Baldrige +1  
[don.b505@comcast.net](mailto:don.b505@comcast.net)

To change component or sample information:  
 Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)

## RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We recommend you service the filters on this component.

## HISTORICAL DIAGNOSIS

### 11 Jul 2023 Diag: Doug Bogart

ISO



We recommend you service the filters on this component. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



### 19 Jul 2022 Diag: Jonathan Hester

DIRT



We recommend you service the filters on this component if applicable. We recommend an early resample to monitor this condition. The iron level is abnormal. There is a high amount of silt (particulates < 14 microns in size) present in the oil. Elemental level of silicon (Si) above normal indicating ingress of seal material. The oil viscosity is higher than normal. Additive levels indicate the addition of a different brand, or type of oil. Confirm oil type. The AN level is acceptable for this fluid.

view report



### 19 Jul 2022 Diag: Jonathan Hester

ISO



No corrective action is recommended at this time. Resample at the next service interval to monitor. All component wear rates are normal. There is a moderate amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


view report





# OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Area  
**Preparation-Prep EB CALENDAR**  
 Machine Id  
**[Preparation-Prep EB CALENDAR] 360014005 - EB CALENDAR MAIN HYD UNIT**  
 Component  
**Hydraulic System**  
 Fluid  
**SHELL TELLUS S2 MX 46 (100 LTR)**

## DIAGNOSIS

### Recommendation

We recommend you service the filters on this component. Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

### Contamination

There is a high amount of particulates present in the oil.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	<b>TLC0001118</b>	TLC0001301	TLC0000817
Sample Date	Client Info	<b>30 Oct 2023</b>	11 Jul 2023	19 Jul 2022
Machine Age	hrs	Client Info	0	0
Oil Age	hrs	Client Info	0	0
Oil Changed	Client Info	<b>N/A</b>	N/A	N/A
Sample Status		<b>ABNORMAL</b>	ABNORMAL	ABNORMAL

## WEAR METALS

method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m >20	<b>0</b>	0	▲ 27
Chromium	ppm	ASTM D5185m >20	<b>0</b>	0	0
Nickel	ppm	ASTM D5185m >20	<b>0</b>	0	<1
Titanium	ppm	ASTM D5185m	<b>0</b>	<1	0
Silver	ppm	ASTM D5185m	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m >20	<b>0</b>	<1	<1
Lead	ppm	ASTM D5185m >20	<b>11</b>	2	<1
Copper	ppm	ASTM D5185m >20	<b>2</b>	2	2
Tin	ppm	ASTM D5185m >20	<b>&lt;1</b>	0	0
Vanadium	ppm	ASTM D5185m	<b>0</b>	<1	0
Cadmium	ppm	ASTM D5185m	<b>0</b>	0	0

## ADDITIVES

method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m 0	<b>0</b>	0	6
Barium	ppm	ASTM D5185m 0	<b>0</b>	0	0
Molybdenum	ppm	ASTM D5185m 0	<b>0</b>	0	0
Manganese	ppm	ASTM D5185m 0	<b>0</b>	0	<1
Magnesium	ppm	ASTM D5185m 70	<b>49</b>	50	▲ 1
Calcium	ppm	ASTM D5185m 10	<b>10</b>	9	▲ 4
Phosphorus	ppm	ASTM D5185m 300	<b>242</b>	258	▲ 273
Zinc	ppm	ASTM D5185m 325	<b>280</b>	288	▲ 22
Sulfur	ppm	ASTM D5185m 665	<b>641</b>	787	▲ 14473

## CONTAMINANTS

method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m >15	<b>0</b>	<1	▲ 15
Sodium	ppm	ASTM D5185m	<b>&lt;1</b>	2	<1
Potassium	ppm	ASTM D5185m >20	<b>0</b>	3	0

## FLUID CLEANLINESS

method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >5000	▲ <b>12460</b>	▲ 18190	▲ 163143
Particles >6µm	ASTM D7647 >1300	▲ <b>2948</b>	▲ 3737	▲ 66700
Particles >14µm	ASTM D7647 >160	▲ <b>265</b>	▲ 187	130
Particles >21µm	ASTM D7647 >40	▲ <b>57</b>	36	17
Particles >38µm	ASTM D7647 >10	<b>1</b>	1	0
Particles >71µm	ASTM D7647 >3	<b>0</b>	0	0
Oil Cleanliness	ISO 4406 (c) >19/17/14	▲ <b>21/19/15</b>	▲ 21/19/15	▲ 25/23/14


## FLUID DEGRADATION

method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D8045 0.35	<b>0.23</b>	0.30	0.50




# OIL ANALYSIS REPORT


### ▲ Particle Trend




### ▲ Particle Trend



### Acid Number




### Viscosity @ 40°C



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG


FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	46.0	45.8	46.4 ▲ 297.6

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------




### GRAPHS


#### Ferrous Alloys




#### Non-ferrous Metals




#### Viscosity @ 40°C



#### ▲ Particle Count



#### Acid Number



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : TLC0001118 **Received** : 03 Nov 2023  
**Lab Number** : 05997913 **Diagnosed** : 06 Nov 2023  
**Unique Number** : 10726273 **Diagnostician** : Don Baldrige  
**Test Package** : PLANT

**MICHELIN US 10**  
 16 BIBB WAY  
 ANDERSON, SC  
 US 29626

Contact: TERRICK PRESLEY  
 terrick.presley@michelin.com  
 T: (803)761-8053  
 F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)