


OIL ANALYSIS REPORT

Sample Rating Trend

NORMAL



Machine Id
H3 - EMULSION

Component
Heat Transfer Fluid
Fluid
ERGON HYGOLD L500 (--- GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor. Please note that this is a corrected copy for data entry update for oil type.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the fluid. The amount and size of particulates present in the system are acceptable.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the fluid is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		TO10002557	---	---
Sample Date	Client Info		31 Oct 2023	---	---
Machine Age	hrs	Client Info	0	---	---
Oil Age	hrs	Client Info	0	---	---
Oil Changed	Client Info		N/A	---	---
Sample Status			NORMAL	---	---

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >200	54	---	---
Chromium	ppm	ASTM D5185m >21	0	---	---
Nickel	ppm	ASTM D5185m >21	0	---	---
Titanium	ppm	ASTM D5185m >21	0	---	---
Silver	ppm	ASTM D5185m >21	0	---	---
Aluminum	ppm	ASTM D5185m >21	0	---	---
Lead	ppm	ASTM D5185m >21	<1	---	---
Copper	ppm	ASTM D5185m >21	0	---	---
Tin	ppm	ASTM D5185m >21	<1	---	---
Vanadium	ppm	ASTM D5185m	0	---	---
Cadmium	ppm	ASTM D5185m	0	---	---

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	---	---
Barium	ppm	ASTM D5185m	0	---	---
Molybdenum	ppm	ASTM D5185m	0	---	---
Manganese	ppm	ASTM D5185m	<1	---	---
Magnesium	ppm	ASTM D5185m	0	---	---
Calcium	ppm	ASTM D5185m	3	---	---
Phosphorus	ppm	ASTM D5185m	1	---	---
Zinc	ppm	ASTM D5185m	0	---	---
Sulfur	ppm	ASTM D5185m 432	301	---	---

CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >25	<1	---	---
Sodium	ppm	ASTM D5185m >21	1	---	---
Potassium	ppm	ASTM D5185m >20	0	---	---
Water	%	ASTM D6304 >0.0601	0.012	---	---
ppm Water	ppm	ASTM D6304 >601	127.0	---	---





FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647		243731	---	---
Particles >6µm	ASTM D7647	>10240000	182838	---	---
Particles >14µm	ASTM D7647	>10240000	17439	---	---
Particles >21µm	ASTM D7647	>2560000	1576	---	---
Particles >38µm	ASTM D7647	>640000	11	---	---
Particles >71µm	ASTM D7647	>160000	1	---	---
Oil Cleanliness	ISO 4406 (c)	>--/30/30	25/25/21	---	---

FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045 0.01	0.16	---	---

OIL ANALYSIS REPORT




VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	---
Yellow Metal	scalar	*Visual	NONE	NONE	---
Precipitate	scalar	*Visual	NONE	NONE	---
Silt	scalar	*Visual	NONE	NONE	---
Debris	scalar	*Visual	NONE	NONE	---
Sand/Dirt	scalar	*Visual	NONE	NONE	---
Appearance	scalar	*Visual	NORML	NORML	---
Odor	scalar	*Visual	NORML	NORML	---
Emulsified Water	scalar	*Visual	>0.0601	NEG	---
Free Water	scalar	*Visual		NEG	---

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	98.9	97.0	---
Visc @ 100°C	cSt	ASTM D445	8.7	9	---
Viscosity Index (VI)	Scale	ASTM D2270	35	50	---

SAMPLE IMAGES

	method	limit/base	current	history1	history2
Color					
Bottom					

GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : TO10002557 **Received** : 03 Nov 2023
Lab Number : 05997965 **Diagnosed** : 08 Nov 2023
Unique Number : 10726325 **Diagnostician** : Doug Bogart
Test Package : IND 2 (Additional Tests: KF, KV100, PrtCount, VI)

ERGMEMAE - MEMPHIS A-E
 1989 CHANNEL AVE
 MEMPHIS, TN
 US 38113
 Contact: JEREMEY CAHER
 Jeremey.Caher@ergmemae.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)