


OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Machine Id
KAESER BSD50 4022749 (S/N 1080)

Component
Compressor

Fluid
KAESER SIGMA (OEM) S-460 (--- QTS)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			KCPA007438	KCP37353	KCP29877
Sample Date	Client Info			12 Oct 2023	26 Aug 2022	15 Nov 2013
Machine Age	hrs	Client Info		38833	36646	12481
Oil Age	hrs	Client Info		0	11877	3692
Oil Changed	Client Info			N/A	Changed	N/A
Sample Status				NORMAL	SEVERE	ATTENTION

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	1304	<1
Chromium	ppm	ASTM D5185m	>10	0	3	0
Nickel	ppm	ASTM D5185m		0	0	0
Titanium	ppm	ASTM D5185m		0	<1	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>25	0	47	<1
Lead	ppm	ASTM D5185m	>25	0	1	<1
Copper	ppm	ASTM D5185m	>50	6	69	7
Tin	ppm	ASTM D5185m	>15	<1	<1	0
Antimony	ppm	ASTM D5185m		---	---	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	<1	0






ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	11	0
Barium	ppm	ASTM D5185m	90	0	<1	5
Molybdenum	ppm	ASTM D5185m		0	<1	0
Manganese	ppm	ASTM D5185m		0	2	0
Magnesium	ppm	ASTM D5185m	90	<1	2	31
Calcium	ppm	ASTM D5185m	2	1	4	<1
Phosphorus	ppm	ASTM D5185m		20	221	2
Zinc	ppm	ASTM D5185m		0	269	34
Sulfur	ppm	ASTM D5185m		2466	426	17600

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	13	<1
Sodium	ppm	ASTM D5185m		0	17	16
Potassium	ppm	ASTM D5185m	>20	0	18	1
Water	%	ASTM D6304	>0.1	0.011	0.357	0.001
ppm Water	ppm	ASTM D6304	>1000	116.4	3570.4	10

FLUID CLEANLINESS		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		662	---	910
Particles >6µm		ASTM D7647	>1300	198	---	495
Particles >14µm		ASTM D7647	>80	21	---	84
Particles >21µm		ASTM D7647	>20	5	---	28
Particles >38µm		ASTM D7647	>4	0	---	4
Particles >71µm		ASTM D7647	>3	0	---	0
Oil Cleanliness		ISO 4406 (c)	>--/17/13	17/15/12	---	16/14

FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	1.13	44.5	0.387


OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	LIGHT	▲ MODER
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	▲ HAZY
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	46	45.9	▲ 178

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : KCPA007438 **Received** : 03 Nov 2023
Lab Number : 05997978 **Diagnosed** : 06 Nov 2023
Unique Number : 10726338 **Diagnostician** : Don Baldrige
Test Package : IND 2 (Additional Tests: KF, PrtCount)

SIMPAK INTERNATIONAL
 10401 BUNSEN WAY
 LOUISVILLE, KY
 US 40299
 Contact:

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:
F: