


PROBLEM SUMMARY

KAESER ASD 40 5978124 (S/N 1390)

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)





COMPONENT CONDITION SUMMARY

No relevant graphs to display

RECOMMENDATION

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.

PROBLEMATIC T	EST RE	SULTS					
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL	
Debrie	coalar	*\/icual	NONE	▲ MODER	▲ MODER	\/ TE	

Customer Id: OZICHIKC Sample No.: KC125204 Lab Number: 05997979 Test Package: IND 2

To manage this report scan the QR code

To discuss the diagnosis or test data:

Don Baldridge +1 don.b505@comcast.net

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Alert			?	We were unable to perform a particle count due to a high concentration of particles present in this sample.

HISTORICAL DIAGNOSIS

01 Jul 2021 Diag: Doug Bogart

WATER



Oil and filter change at the time of sampling has been noted. We recommend an early resample in 500 hours to monitor this condition. We were unable to perform a particle count due to a high concentration of particles present in this sample. All component wear rates are normal. Moderate concentration of visible dirt/debris present in the oil. There is a light concentration of water present in the oil. The AN level is acceptable for this fluid.



28 Feb 2018 Diag: Angela Borella

ISO



Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

KAESER ASD 40 5978124 (S/N 1390)

Component

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.

Wear

All component wear rates are normal.

Contamination

Moderate concentration of visible dirt/debris present in the oil.


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


		Fel	2018	Jul2021 0et20	23	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC125204	KC98999	KC80354
Sample Date		Client Info		04 Oct 2023	01 Jul 2021	28 Feb 2018
Machine Age	hrs	Client Info		64848	31622	3849
Oil Age	hrs	Client Info		0	6000	3849
Oil Changed		Client Info		N/A	Changed	Changed
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	2
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	<1	0
Aluminum	ppm	ASTM D5185m	>10	0	0	1
Lead	ppm	ASTM D5185m	>10	0	0	<1
Copper	ppm	ASTM D5185m	>50	14	7	5
Tin	ppm	ASTM D5185m	>10	<1	<1	<1
Antimony	ppm	ASTM D5185m			0	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	14	0
Barium	ppm	ASTM D5185m	90	54	0	6
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	0	0
Magnesium	ppm	ASTM D5185m	90	53	<1	41
Calcium	ppm	ASTM D5185m	2	2	<1	<1
Phosphorus	ppm	ASTM D5185m		1	1	41
Zinc	ppm	ASTM D5185m		0	4	16
CONTAMINANTS	}	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	<1	<1
Sodium	ppm	ASTM D5185m		0	<1	12
Potassium	ppm	ASTM D5185m	>20	0	0	2
Water	%	ASTM D6304	>0.05	0.020	<u>^</u> 0.235	0.010
ppm Water	ppm	ASTM D6304	>500	205.0	<u>^</u> 2350	100
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4μm		ASTM D7647				28595
Particles >6µm		ASTM D7647	>1300			<u></u> 9809
Particles >14μm		ASTM D7647	>80			<u>^</u> 287
Particles >21µm		ASTM D7647	>20			<u>4</u> 0
Particles >38µm		ASTM D7647	>4			2
Particles >71μm		ASTM D7647	>3			0
Oil Cleanliness		ISO 4406 (c)	>/17/13			<u>^</u> 20/15
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.39	0.387	0.359





OIL ANALYSIS REPORT



Non-ferrous Metals











Certificate L2367

Laboratory Sample No. Lab Number **Unique Number** Test Package

: KC125204 : 05997979 : 10726339 : IND 2

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received Diagnosed Diagnostician

: 03 Nov 2023 : 06 Nov 2023 : Don Baldridge **OZINGA MATERIALS INC** 11701 S TORRENCE AVE

CHICAGO, IL US 60617

Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: F: