

PROBLEM SUMMARY

Machine Id 2671561 (S/N 1267) Component


Compressor Fluid KAESER SIGMA (OEM) S-460 (--- GAL)

COMPONENT CONDITION SUMMARY



WATER

Sample Rating Trend



RECOMMENDATION

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS

FRODLEWATIO		50L15				
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
Water	%	ASTM D6304	>0.05	A 0.064	0.021	0.034
ppm Water	ppm	ASTM D6304	>500	🔺 647.4	210.7	344.0
Particles >6µm		ASTM D7647	>1300	A 3197	1 4687	<u> </u>
Particles >14µm		ASTM D7647	>80	A 236	🔺 1142	<u> </u>
Particles >21µm		ASTM D7647	>20	<u> </u>	1 67	8 3
Oil Cleanliness		ISO 4406 (c)	>/17/13	🔺 21/19/15	🔺 22/21/17	1 9/15

Customer Id: FULUNIKC Sample No.: KC125934 Lab Number: 05997986 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Don Baldridge +1 <u>don.b505@comcast.net</u>

To change component or sample information: Customer Service +1 1-800-237-1369 <u>customerservice@wearcheck.com</u>

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

09 Jun 2022 Diag: Jonathan Hester



Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

26 Jun 2020 Diag: Angela Borella



Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



view report







OIL ANALYSIS REPORT

SAMPLE INCODMATION

Sample Rating Trend WATER

Machine Id 2671561 (S/N 1267) Component

Compressor Fluid KAESER SIGMA (OEM) S-460 (--- GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil. There is a trace of moisture present in the oil.

Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC125934	KC104847	KC83221
Sample Date		Client Info		31 Oct 2023	09 Jun 2022	26 Jun 2020
Machine Age	hrs	Client Info		40704	37491	32100
Oil Age	hrs	Client Info		0	5391	3294
Oil Changed		Client Info		N/A	Changed	Changed
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	<1	<1
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m	>2	0	<1	0
Aluminum	ppm	ASTM D5185m	>10	0	<1	0
Lead	ppm	ASTM D5185m	>10	0	0	<1
Copper	ppm	ASTM D5185m		1	7	2
Tin	ppm	ASTM D5185m	>10	<1	0	0
Antimony	ppm	ASTM D5185m	-			0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
	1.1		11			
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	<1
Barium	ppm	ASTM D5185m	90	4	0	2
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		<1	0	0
Magnesium	ppm	ASTM D5185m	90	58	38	58
Calcium	ppm	ASTM D5185m	2	2	0	2
Phosphorus	ppm	ASTM D5185m		1	31	2
Zinc	ppm	ASTM D5185m		8	23	0
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	4	1
Sodium	ppm	ASTM D5185m		14	12	16
Potassium	ppm	ASTM D5185m	>20	<1	0	2
Water	%	ASTM D6304	>0.05	<u> </u>	0.021	0.034
ppm Water	ppm	ASTM D6304	>500	647.4	210.7	344.0
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		10750	39131	5973
Particles >6µm		ASTM D7647	>1300	<u> </u>	1 4687	<u> </u>
Particles >14µm		ASTM D7647	>80	<u> </u>	1 142	2 98
Particles >21µm		ASTM D7647	>20	<u> </u>	1 67	<u> </u>
Particles >38µm		ASTM D7647	>4	1	5	1 6
Particles >71µm		ASTM D7647	>3	0	0	<u> </u>
Oil Cleanliness		ISO 4406 (c)	>/17/13	A 21/19/15	A 22/21/17	▲ 19/15
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.35	0.36	0.359


Contact/Location: Service Manager - FULUNIKC



OIL ANALYSIS REPORT








VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	LIGHT	LIGHT	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERT	IES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	46	46.0	46.8	46.3
SAMPLE IMAGES	S	method	limit/base	current	history1	history2
Color						

Bottom



Contact/Location: Service Manager - FULUNIKC