


# **OIL ANALYSIS REPORT**



**NORMAL** 



# KAESER 7268042

Component

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

### Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

### Contamination

The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil.


### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		May2021	Nov2021 Jun2022	. Nov2022 Aug2023	0ct2023	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC125931	KC123086	KC106720
Sample Date		Client Info		12 Oct 2023	02 Aug 2023	29 Nov 2022
Machine Age	hrs	Client Info		13986	13173	9925
Oil Age	hrs	Client Info		0	0	5560
Oil Changed		Client Info		N/A	N/A	Changed
Sample Status				NORMAL	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	<1
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	0	0	2
Lead	ppm	ASTM D5185m	>10	<1	0	0
Copper	ppm	ASTM D5185m	>50	<1	1	2
Tin	ppm	ASTM D5185m	>10	<1	<1	<1
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m	90	9	19	<1
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		<1	<1	0
Magnesium	ppm	ASTM D5185m	90	69	72	65
Calcium	ppm	ASTM D5185m	2	3	2	<1
Phosphorus	ppm	ASTM D5185m		1	3	20
Zinc	ppm	ASTM D5185m		4	3	0
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	1	<1
Sodium	ppm	ASTM D5185m		17	15	16
Potassium	ppm	ASTM D5185m	>20	2	3	1
Water	%	ASTM D6304	>0.05	0.024	<b>△</b> 0.146	0.018
ppm Water	ppm	ASTM D6304	>500	240.6	<u>▲</u> 1460	180.9
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4μm		ASTM D7647		138	1975	15777
Particles >6µm		ASTM D7647	>1300	41	1076	<b>△</b> 6998
Particles >14µm		ASTM D7647	>80	7	<b>▲</b> 183	<b>△</b> 613
Particles >21µm		ASTM D7647	>20	3	<b>△</b> 62	<u></u> 84
Particles >38μm		ASTM D7647	>4	1	<b>1</b> 0	2
Particles >71μm		ASTM D7647	>3	1	1	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	14/13/10	▲ 18/17/15	<b>△</b> 21/20/16
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.34	0.38	0.31



## **OIL ANALYSIS REPORT**



Certificate L2367

Test Package

: IND 2

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: F:

Contact: Service Manager