


PROBLEM SUMMARY

Sample Rating Trend



WATER




Machine Id
KAESER ESD 250 4353280 (S/N 1040)

Component
Compressor

Fluid
KAESER SIGMA (OEM) S-460 (--- QTS)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

We advise that you check for a possible overheat condition. The filter change at the time of sampling has been noted. We advise that you stop the unit and follow the water drain-off procedure for this component. We recommend an early resample in 500 hours to monitor this condition.

PROBLEMATIC TEST RESULTS

| Sample Status | | | | ABNORMAL | ABNORMAL | NORMAL |
|------------------|----------|--------------|-----------|-------------------|----------|--------|
| Water | % | ASTM D6304 | >0.05 | ▲ 0.067 | 0.010 | 0.006 |
| ppm Water | ppm | ASTM D6304 | >500 | ▲ 671.4 | 100 | 60 |
| Particles >6µm | | ASTM D7647 | >1300 | ▲ 5105 | ▲ 43727 | 83 |
| Oil Cleanliness | | ISO 4406 (c) | >--/17/13 | ▲ 23/20/12 | ▲ 23/19 | 14/11 |
| Acid Number (AN) | mg KOH/g | ASTM D8045 | 0.4 | ▲ 1.60 | 0.472 | 0.490 |
| Visc @ 40°C | cSt | ASTM D445 | 46 | ▲ 65.2 | 49.1 | 50.08 |

Customer Id: RIVLOUKY
Sample No.: KCPA009125
Lab Number: 05997999
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
Jonathan Hester +1 919-379-4092 x4092
jhester@wearcheckusa.com

To change component or sample information:
Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

| Action | Status | Date | Done By | Description |
|-----------------------|--------|------|---------|---|
| Check For Overheating | --- | --- | ? | We advise that you check for a possible overheat condition. |

HISTORICAL DIAGNOSIS

23 Aug 2019 Diag: Angela Borella

ISO



No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



01 Apr 2019 Diag: Doug Bogart

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the component. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



31 May 2017 Diag: Don Baldrige

NORMAL




Resample at the next service interval to monitor. All component wear rates are normal. The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the component. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



OIL ANALYSIS REPORT

Sample Rating Trend



WATER



Machine Id
KAESER ESD 250 4353280 (S/N 1040)

Component
Compressor

Fluid
KAESER SIGMA (OEM) S-460 (--- QTS)

DIAGNOSIS

▲ Recommendation

We advise that you check for a possible overheat condition. The filter change at the time of sampling has been noted. We advise that you stop the unit and follow the water drain-off procedure for this component. We recommend an early resample in 500 hours to monitor this condition.

Wear

All component wear rates are normal.

▲ Contamination

There is a high amount of silt (particulates < 14 microns in size) present in the oil. There is a light concentration of water present in the oil.

▲ Fluid Condition

The AN level is above the recommended limit. The oil viscosity is higher than normal. The oil is no longer serviceable.

| SAMPLE INFORMATION | | method | limit/base | current | history1 | history2 |
|--------------------|-------------|-------------|------------|--------------------|-------------|-------------|
| Sample Number | Client Info | | | KCPA009125 | KCP16694 | KCP16837 |
| Sample Date | Client Info | | | 27 Oct 2023 | 23 Aug 2019 | 01 Apr 2019 |
| Machine Age | hrs | Client Info | | 33477 | 22096 | 19802 |
| Oil Age | hrs | Client Info | | 0 | 2300 | 6618 |
| Oil Changed | Client Info | | | N/A | Not Changd | Changed |
| Sample Status | | | | ABNORMAL | ABNORMAL | NORMAL |

| WEAR METALS | | method | limit/base | current | history1 | history2 |
|-------------|-----|-------------|------------|--------------|----------|----------|
| Iron | ppm | ASTM D5185m | >50 | 2 | 1 | 0 |
| Chromium | ppm | ASTM D5185m | >10 | <1 | 0 | 0 |
| Nickel | ppm | ASTM D5185m | >3 | 0 | 0 | <1 |
| Titanium | ppm | ASTM D5185m | >3 | 0 | 0 | 0 |
| Silver | ppm | ASTM D5185m | >2 | 0 | 0 | 0 |
| Aluminum | ppm | ASTM D5185m | >10 | 2 | 1 | 0 |
| Lead | ppm | ASTM D5185m | >10 | 0 | 0 | 0 |
| Copper | ppm | ASTM D5185m | >50 | <1 | 7 | 12 |
| Tin | ppm | ASTM D5185m | >10 | 0 | 0 | 0 |
| Antimony | ppm | ASTM D5185m | | --- | 0 | 0 |
| Vanadium | ppm | ASTM D5185m | | 0 | 0 | 0 |
| Cadmium | ppm | ASTM D5185m | | 0 | 0 | 0 |






| ADDITIVES | | method | limit/base | current | history1 | history2 |
|------------|-----|-------------|------------|------------|----------|----------|
| Boron | ppm | ASTM D5185m | | 0 | 0 | <1 |
| Barium | ppm | ASTM D5185m | 90 | 0 | 0 | 0 |
| Molybdenum | ppm | ASTM D5185m | | 0 | <1 | 0 |
| Manganese | ppm | ASTM D5185m | | 0 | 0 | <1 |
| Magnesium | ppm | ASTM D5185m | 90 | 1 | 0 | 0 |
| Calcium | ppm | ASTM D5185m | 2 | 1 | 0 | 0 |
| Phosphorus | ppm | ASTM D5185m | | 0 | <1 | 28 |
| Zinc | ppm | ASTM D5185m | | 9 | 2 | 0 |
| Sulfur | ppm | ASTM D5185m | | 194 | 20063 | 19068 |

| CONTAMINANTS | | method | limit/base | current | history1 | history2 |
|--------------|-----|-------------|------------|----------------|----------|----------|
| Silicon | ppm | ASTM D5185m | >25 | <1 | <1 | <1 |
| Sodium | ppm | ASTM D5185m | | <1 | <1 | <1 |
| Potassium | ppm | ASTM D5185m | >20 | <1 | <1 | 0 |
| Water | % | ASTM D6304 | >0.05 | ▲ 0.067 | 0.010 | 0.006 |
| ppm Water | ppm | ASTM D6304 | >500 | ▲ 671.4 | 100 | 60 |

| FLUID CLEANLINESS | | method | limit/base | current | history1 | history2 |
|-------------------|--|--------------|------------|-------------------|----------|----------|
| Particles >4µm | | ASTM D7647 | | 65461 | 112038 | 452 |
| Particles >6µm | | ASTM D7647 | >1300 | ▲ 5105 | ▲ 43727 | 83 |
| Particles >14µm | | ASTM D7647 | >80 | 28 | ▲ 3625 | 11 |
| Particles >21µm | | ASTM D7647 | >20 | 9 | ▲ 731 | 3 |
| Particles >38µm | | ASTM D7647 | >4 | 0 | ▲ 27 | 0 |
| Particles >71µm | | ASTM D7647 | >3 | 0 | 3 | 0 |
| Oil Cleanliness | | ISO 4406 (c) | >--/17/13 | ▲ 23/20/12 | ▲ 23/19 | 14/11 |

| FLUID DEGRADATION | | method | limit/base | current | history1 | history2 |
|-------------------|----------|------------|------------|---------------|----------|----------|
| Acid Number (AN) | mg KOH/g | ASTM D8045 | 0.4 | ▲ 1.60 | 0.472 | 0.490 |

OIL ANALYSIS REPORT








| VISUAL | method | limit/base | current | history1 | history2 | |
|------------------|--------|------------|---------|--------------|----------|-------|
| White Metal | scalar | *Visual | NONE | LIGHT | NONE | NONE |
| Yellow Metal | scalar | *Visual | NONE | NONE | NONE | NONE |
| Precipitate | scalar | *Visual | NONE | NONE | NONE | NONE |
| Silt | scalar | *Visual | NONE | NONE | NONE | NONE |
| Debris | scalar | *Visual | NONE | LIGHT | VLITE | NONE |
| Sand/Dirt | scalar | *Visual | NONE | NONE | NONE | NONE |
| Appearance | scalar | *Visual | NORML | NORML | NORML | NORML |
| Odor | scalar | *Visual | NORML | NORML | NORML | NORML |
| Emulsified Water | scalar | *Visual | >0.05 | NEG | NEG | NEG |
| Free Water | scalar | *Visual | | NEG | NEG | NEG |

| FLUID PROPERTIES | method | limit/base | current | history1 | history2 |
|------------------|--------|--------------|---------------|----------|----------|
| Visc @ 40°C | cSt | ASTM D445 46 | ▲ 65.2 | 49.1 | 50.08 |

| SAMPLE IMAGES | method | limit/base | current | history1 | history2 |
|---------------|--------|------------|---------|----------|----------|
|---------------|--------|------------|---------|----------|----------|



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : KCPA009125 **Received** : 03 Nov 2023
Lab Number : 05997999 **Diagnosed** : 08 Nov 2023
Unique Number : 10726359 **Diagnostician** : Jonathan Hester
Test Package : IND 2 (Additional Tests: KF, PrtCount)

RIVER METALS
 2114 METAL LN
 LOUISVILLE, KY
 US 40206
 Contact:

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:
F: