


# **OIL ANALYSIS REPORT**

# [K51012] KAESER 7904572 (S/N 1052)

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)





### Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

### Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

			Jun2023	Oct2023		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC50328	KC101195	
Sample Date		Client Info		24 Oct 2023	06 Jun 2023	
Machine Age	hrs	Client Info		16923	13545	
Oil Age	hrs	Client Info		6341	2963	
Oil Changed		Client Info		Changed	Not Changd	
Sample Status				NORMAL	NORMAL	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	
Chromium	ppm	ASTM D5185m	>10	0	0	
Nickel	ppm	ASTM D5185m	>3	0	0	
Titanium	ppm	ASTM D5185m	>3	0	0	
Silver	ppm	ASTM D5185m	>2	0	<1	
Aluminum	ppm	ASTM D5185m	>10	2	<1	
Lead	ppm	ASTM D5185m	>10	0	0	
Copper	ppm	ASTM D5185m	>50	6	3	
Tin	ppm	ASTM D5185m	>10	<1	0	
Vanadium	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	
Barium	ppm	ASTM D5185m	90	0	3	
Molybdenum	ppm	ASTM D5185m		0	0	
Manganese	ppm	ASTM D5185m		<1	0	
Magnesium	ppm	ASTM D5185m	90	5	20	
Calcium	ppm	ASTM D5185m	2	1	0	
Phosphorus	ppm	ASTM D5185m		1	1	
Zinc	ppm	ASTM D5185m		8	3	
CONTAMINANTS	\$	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	<1	
Sodium	ppm	ASTM D5185m		2	2	
Potassium	ppm	ASTM D5185m	>20	1	2	
Water	%	ASTM D6304	>0.05	0.004	0.019	
ppm Water	ppm	ASTM D6304	>500	47.0	194.8	
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		1412	970	
Particles >6µm		ASTM D7647	>1300	362	456	
Particles >14µm		ASTM D7647	>80	26	35	
Particles >21µm		ASTM D7647	>20	5	6	
Particles >38µm		ASTM D7647	>4	0	0	
Particles >71μm		ASTM D7647	>3	0	0	
Oil Cleanliness		ISO 4406 (c)	>/17/13	18/16/12	17/16/12	
FLUID DEGRADA	NOITA	method	limit/base	current	history1	history2
A : INI   (AND		A OTA A DOC 45	0.4		0.00	

Acid Number (AN)


mg KOH/g ASTM D8045 0.4

0.32

0.26



## **OIL ANALYSIS REPORT**







Certificate L2367

Sample No. Lab Number **Unique Number** Test Package

: KC50328 : 05998009 : 10726369

: IND 2

: 03 Nov 2023 Received Diagnosed : 06 Nov 2023

: Don Baldridge Diagnostician

64 ADAMS RD GREENFIELD, MA US 01301 Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: F: