

# **OIL ANALYSIS REPORT**

Sample Rating Trend

### NORMAL

## VAC LL-7 (S/N F13093U96127) Component

Pump Fluid **USPI VAC 100 (--- GAL)** 

#### Recommendation

Resample at the next service interval to monitor.

#### Wear


All component wear rates are normal.

#### Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

#### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



m2017 Nov2017 Sup2018 Ju2019 Fm22020 Dm22020 Nov2021 Ju2023									
SAMPLE INFORM	<b>IATION</b>	method	limit/base	current	history1	history2			
Sample Number		Client Info		USPM31145	USPM5905501	USPM28630			
Sample Date		Client Info		02 Nov 2023	18 Jul 2023	14 Apr 2023			
Machine Age	hrs	Client Info		0	0	0			
Oil Age	hrs	Client Info		0	0	0			
Oil Changed		Client Info		N/A	N/A	N/A			
Sample Status				NORMAL	NORMAL	ATTENTION			
WEAR METALS		method	limit/base	current	history1	history2			
Iron	ppm	ASTM D5185m	>90	<1	2	9			
Chromium	ppm	ASTM D5185m	>5	0	0	0			
Nickel	ppm	ASTM D5185m	>5	<1	0	0			
Titanium	ppm	ASTM D5185m	>3	0	0	0			
Silver	ppm	ASTM D5185m	>3	0	<1	0			
Aluminum	ppm	ASTM D5185m	>7	<1	0	2			
Lead	ppm	ASTM D5185m	>12	<1	0	0			
Copper	ppm	ASTM D5185m	>30	0	0	<1			
Tin	ppm	ASTM D5185m	>9	1	0	0			
Vanadium	ppm	ASTM D5185m		0	0	0			
Cadmium	ppm	ASTM D5185m		0	0	0			
ADDITIVES		method	limit/base	current	history1	history2			
Boron	ppm	ASTM D5185m	0	0	0	0			
Barium	ppm	ASTM D5185m	0	0	<1	0			
Molybdenum	ppm	ASTM D5185m	0	0	0	<1			
Manganese	ppm	ASTM D5185m		0	0	<1			
Magnesium	ppm	ASTM D5185m	0	<1	0	8			
Calcium	ppm	ASTM D5185m	0	2	0	<u> </u>			
Phosphorus	ppm	ASTM D5185m	1800	783	790	<b>1</b> 30			
Zinc	ppm	ASTM D5185m	0	0	0	<u> </u>			
Sulfur	ppm	ASTM D5185m	0	24	0	<b>4</b> 95			
CONTAMINANTS	;	method	limit/base	current	history1	history2			
Silicon	ppm	ASTM D5185m	>60	23	17	18			
Sodium	ppm	ASTM D5185m		0	0	47			
Potassium	ppm	ASTM D5185m	>20	1	<1	4			
Water	%	ASTM D6304	>.1	0.028	0.059	0.009			
ppm Water	ppm	ASTM D6304	>1000	289.2	599.8	98.3			
	IESS		limit/base		history1	history2			


FLUID CLEANLINESS	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>5000	482	2539	1224
Particles >6µm	ASTM D7647	>1300	174	610	411
Particles >14µm	ASTM D7647	>160	23	32	41
Particles >21µm	ASTM D7647	>40	7	7	9
Particles >38µm	ASTM D7647	>10	0	0	1
Particles >71µm	ASTM D7647	>3	0	0	0
Oil Cleanliness	ISO 4406 (c)	>19/17/14	16/15/12	19/16/12	17/16/13
FLUID DEGRADATION	method	limit/base	current	history1	history2
Acid Number (AN) mg KOH/g	ASTM D8045	0.05	0.361	0.058	0.18


Report Id: SMISPRIOHI [WUSCAR] 05998039 (Generated: 11/06/2023 22:56:23) Rev: 1


Contact/Location: ? ? - SMISPRIOHI




# **OIL ANALYSIS REPORT**












Bottom



: Doug Bogart

801 E. KEMPER RD SPRINGDALE, OH US 45246 Contact:

To discuss this sample report, contact Customer Service at 1-800-237-1369.

: 10726399

: IND 2

Unique Number

Test Package

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Diagnostician

Certificate L2367

Contact/Location: ? ? - SMISPRIOHI

T:

F: