


OIL ANALYSIS REPORT







KAESER 8299768

Component

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

			Aug ² 022	0ct2023		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC126195	KC104958	
Sample Date		Client Info		11 Oct 2023	26 Aug 2022	
Machine Age	hrs	Client Info		4868	2048	
Oil Age	hrs	Client Info		0	2048	
Oil Changed		Client Info		N/A	Changed	
Sample Status				NORMAL	ABNORMAL	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	2	
Chromium	ppm	ASTM D5185m	>10	0	0	
Nickel	ppm	ASTM D5185m	>3	0	0	
Titanium	ppm	ASTM D5185m	>3	0	0	
Silver	ppm	ASTM D5185m	>2	0	0	
Aluminum	ppm	ASTM D5185m	>10	0	<1	
Lead	ppm	ASTM D5185m	>10	0	<1	
Copper	ppm	ASTM D5185m	>50	12	10	
Tin	ppm	ASTM D5185m	>10	0	<1	
Vanadium	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	
Barium	ppm	ASTM D5185m	90	0	0	
Molybdenum	ppm	ASTM D5185m		0	0	
Manganese	ppm	ASTM D5185m		0	<1	
Magnesium	ppm	ASTM D5185m	90	4	32	
Calcium	ppm	ASTM D5185m	2	0	0	
Phosphorus	ppm	ASTM D5185m		0	3	
Zinc	ppm	ASTM D5185m		9	5	
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0	<1	
Sodium	ppm	ASTM D5185m		2	7	
Potassium	ppm	ASTM D5185m	>20	0	1	
Water	%	ASTM D6304	>0.05	0.009	0.020	
ppm Water	ppm	ASTM D6304	>500	93.8	207.6	
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		2346	6619	
Particles >6µm		ASTM D7647	>1300	630	<u>▲</u> 2794	
Particles >14μm		ASTM D7647	>80	60	<u>^</u> 218	
Particles >21µm		ASTM D7647	>20	20	△ 29	
Particles >38μm		ASTM D7647	>4	1	2	
Particles >71µm		ASTM D7647	>3	0	0	
Oil Cleanliness		ISO 4406 (c)	>/17/13	18/16/13	2 0/19/15	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
	1/011/	4 OT1 4 D 00 4 F	0.4			

Acid Number (AN)


mg KOH/g ASTM D8045 0.4

0.36

0.35



OIL ANALYSIS REPORT







Certificate L2367

Lab Number Unique Number Test Package

: 05998453 : 10726813

Diagnosed

: 07 Nov 2023 : Don Baldridge Diagnostician

TWINSBURG, OH US 44087 Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.

: IND 2

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: F: