




# OIL ANALYSIS REPORT

## Sample Rating Trend



ISO



Machine Id  
**RECIRC**

Component  
**Hydraulic System**

Fluid  
**R&O OIL ISO 32 (--- GAL)**

### DIAGNOSIS

#### Recommendation

The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

#### Contamination

There is a moderate amount of particulates present in the oil.

#### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

### SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>PTK0004325</b>	PTK0004324	PTK0004327
Sample Date	Client Info		<b>23 Oct 2023</b>	14 Jun 2023	02 May 2023
Machine Age	days	Client Info	<b>170</b>	40	0
Oil Age	days	Client Info	<b>0</b>	0	0
Oil Changed	Client Info		<b>Not Changed</b>	Not Changed	Not Changed
Sample Status			<b>ATTENTION</b>	ATTENTION	ABNORMAL

### WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >20	<b>0</b>	<1	<1
Chromium	ppm	ASTM D5185m >10	<b>0</b>	1	0
Nickel	ppm	ASTM D5185m >10	<b>0</b>	<1	0
Titanium	ppm	ASTM D5185m	<b>0</b>	1	0
Silver	ppm	ASTM D5185m	<b>0</b>	<1	0
Aluminum	ppm	ASTM D5185m >10	<b>0</b>	0	<1
Lead	ppm	ASTM D5185m >10	<b>0</b>	<1	0
Copper	ppm	ASTM D5185m >75	<b>&lt;1</b>	<1	<1
Tin	ppm	ASTM D5185m >10	<b>0</b>	1	0
Vanadium	ppm	ASTM D5185m	<b>0</b>	2	0
Cadmium	ppm	ASTM D5185m	<b>0</b>	<1	0

### ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m 5	<b>0</b>	0	0
Barium	ppm	ASTM D5185m 5	<b>0</b>	0	0
Molybdenum	ppm	ASTM D5185m 5	<b>0</b>	<1	0
Manganese	ppm	ASTM D5185m	<b>0</b>	<1	<1
Magnesium	ppm	ASTM D5185m 5	<b>0</b>	<1	<1
Calcium	ppm	ASTM D5185m 5	<b>73</b>	2	82
Phosphorus	ppm	ASTM D5185m 100	<b>316</b>	0	359
Zinc	ppm	ASTM D5185m 25	<b>402</b>	0	452
Sulfur	ppm	ASTM D5185m 1500	<b>1064</b>	0	1074

### CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >20	<b>1</b>	1	2
Sodium	ppm	ASTM D5185m	<b>0</b>	30	0
Potassium	ppm	ASTM D5185m >20	<b>0</b>	7	0





### FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>5000	<b>3213</b>	8723	111077
Particles >6µm	ASTM D7647	>1300	<b>1028</b>	▲ 2962	▲ 45608
Particles >14µm	ASTM D7647	>160	▲ <b>178</b>	256	▲ 3347
Particles >21µm	ASTM D7647	>40	▲ <b>67</b>	54	▲ 320
Particles >38µm	ASTM D7647	>10	<b>4</b>	1	5
Particles >71µm	ASTM D7647	>3	<b>0</b>	0	0
Oil Cleanliness	ISO 4406 (c)	>19/17/14	▲ <b>19/17/15</b>	▲ 20/19/15	▲ 24/23/19

### FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045 0.08	<b>0.23</b>	0.21	0.24


# OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	LIGHT
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	LIGHT
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445 32	<b>32.6</b>	32.8	32.9

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : PTK0004325 **Received** : 06 Nov 2023  
**Lab Number** : 05999020 **Diagnosed** : 07 Nov 2023  
**Unique Number** : 10727380 **Diagnostician** : Doug Bogart  
**Test Package** : MOB 2

**OLDCASTLE**  
 103 YELLOWBROOK RD  
 FARMINGDALE, NJ  
 US 07727  
 Contact: SHAUN COLEMAN  
 shaun.coleman@oldcastle.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)