

OIL ANALYSIS REPORT

ROTO Z ATLAS COPCO 5988861-03 - UNIT 4 (S/N S988861-03)

Compressor



Sample Rating Trend



Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is no indication of any contamination in the


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in

				Nov2023		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		UCH05999117		
Sample Date		Client Info		02 Nov 2023		
Machine Age	hrs	Client Info		53562		
Oil Age	hrs	Client Info		2000		
Oil Changed		Client Info		Not Changd		
Sample Status				NORMAL		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1		
Chromium	ppm	ASTM D5185m	>5	0		
Nickel		ASTM D5185m	70	0		
Titanium	ppm	ASTM D5185m		0		
Silver	ppm					
Aluminum	ppm	ASTM D5185m	>15	0 <1		
	ppm	ASTM D5185m				
Lead	ppm	ASTM D5185m	>65	0		
Copper	ppm	ASTM D5185m	>65	0		
Tin	ppm	ASTM D5185m	>10	0		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m		0		
Molybdenum	ppm	ASTM D5185m		0		
Manganese	ppm	ASTM D5185m		0		
Magnesium	ppm	ASTM D5185m		0		
Calcium	ppm	ASTM D5185m		7		
Phosphorus	ppm	ASTM D5185m		427		
Zinc	ppm	ASTM D5185m		28		
Sulfur	ppm	ASTM D5185m		691		
CONTAMINANTS	5	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>35	0		
Sodium	ppm	ASTM D5185m		<1		
Potassium	ppm	ASTM D5185m	>20	0		
FLUID DEGRADA	NOITA	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.27		
VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE		
Yellow Metal	scalar	*Visual	NONE	NONE		
Precipitate	scalar	*Visual	NONE	NONE		
Silt	scalar	*Visual	NONE	NONE		
Debris	scalar	*Visual	NONE	LIGHT		
Sand/Dirt	scalar	*Visual	NONE	NONE		
Appearance	scalar	*Visual	NORML	NORML		
Odor	scalar	*Visual	NORML	NORML		
Emulsified Water	scalar	*Visual	>0.1	NEG		
Free Water	scalar	*Visual		NEG		
·20·31) Ray: 1					n: APRIL MOO	DE LICDIDMI



OIL ANALYSIS REPORT







Laboratory Sample No. Lab Number Test Package : IND 2

Unique Number : 10727477

: UCH05999117 : 05999117

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 06 Nov 2023 Diagnosed : 07 Nov 2023 Diagnostician : Angela Borella

DIRECT AIR - AIR TECHNOLOGIES

400 WRIGHT AVE MIDDLETOWN, OH US 45044

Contact: APRIL MOORE

april.moore@aircompressors.com

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

F: (513)539-6040